



**UNIVERSITY OF NAIROBI**  
**DEPARTMENT OF MECHANICAL ENGINEERING**

**GACHAU KENNEDY NJAGI**

**F56/75171/2014**

**MSc. (ENG) Energy Management**

**IDENTIFYING ENERGY SAVING OPPORTUNITIES IN A COMMERCIAL  
BUILDING IN NAIROBI:**

**A CASE STUDY OF EQUATORIAL FIDELITY CENTRE IN WESTLANDS NAIROBI.**

## **DECLARATION**

I declare that this work has not been previously submitted and approved for the award of a degree by this or other University. To the best of my knowledge and belief, the project report contains no material previously published or written by another person except where due reference is made in the report itself.

**KENNEDY NJAGI GACHAU**

**Sign:**.....

**Date:**.....

### **Approval**

The project report of Kennedy Njagi Gachau was reviewed and approved by the following:

**Dr. Cyrus Wekesa**

**Prof. J.M. Mbutia**

## **ACKNOWLEDGEMENTS**

Firstly, I wish to thank God for the good health and peace of mind during the entire period of my study and project.

I also thank my supervisors for their valuable assistance and guidance throughout the project. The willingness to provide direction, focus and feedback is highly appreciated.

Special thanks go to my entire family and colleagues for their support and understanding during the project.

# Table of Contents

CHAPTER ONE: INTRODUCTION.....	1
1.1 Introduction and Background.....	1
1.1.1 Equatorial Fidelity Centre (EFL), .....	2
1.2 Problem Statement .....	4
1.3 Research Objectives .....	5
CHAPTER 2: LITERATURE REVIEW.....	7
2.1 Energy Savings.....	7
2.2.1 Consumer Categories in Kenya .....	9
2.3 Solar Photovoltaic for Commercial Buildings .....	12
2.4 Electrical Systems in Commercial Buildings.....	13
2.5 Day lighting and Illumination in Commercial Buildings.....	15
2.5.1 Daylight and energy in Buildings .....	15
2.5.2: Innovative Daylight Systems .....	16
2.5.3 Typical Light Transport Systems.....	17
2.5.4 Light Collection for light transport systems. ....	20
2.5.5 Efficiency of Light Pipe.....	22
2.5.6 Light Extraction .....	22
CHAPTER 3: METHODOLOGY .....	24
3.1 Technical Energy Audit Evaluation .....	24
3.1.2 Historical Data .....	26
3.2 Assessment on the use of Day lighting in the basement of EFC.....	26
3.3 Assessment on the use of Solar Panels.....	26
CHAPTER 4: RESULTS AND ANALYSIS .....	28
4.1 INTRODUCTION.....	28
4.1.1 Energy Sources at EFC .....	28
4.1.2 KPLC Main Incomer.....	29
4.1 Historical Information.....	31
4.2. IDENTIFIED ENERGY SAVING OPPORTUNITIES .....	32
4.2.1 ENERGY SAVINGS BY USE OF LIGHT PIPE IN THE BASEMENT. ....	32
4.2.2 .USE OF LEDs TO REPLACE EXIXTING FLUORESCENT TUBE LAMPS. ....	36
4.2.3. ENERGY SAVINGS THROUGH SOLAR PV .....	42

4.2.4 POWER FACTOR IMPROVEMENT. ....	48
4.2.5: TARIFF MIGRATION.....	53
4.3 ECONOMIC EVALUATION FOR IMPLEMENTATION OF THE OUTLINED MEASURES.....	54
4.4 PAYBACK PERIOD OF THE ENERGY SAVING MEASURES OUTLINED .....	58
CHAPTER 5: CONCLUSIONS AND RECOMMENDATIONS.....	60
7. REFERENCES .....	63

## LIST OF TABLES

Table 4.1 Category of Energy Consumers	1
Table 1.2 Baseline information for EFC	3
Table 1.3 Historical Energy Consumption in EFC	5
Table 2.1 Summary of Proposed Retail Tariffs	9
Table 2.2 Surcharges applied in all Tariffs	10
Table 2.3 Energy Demand in Kenya	11
Table 3.1 Measurements Tools	24
Table 3.2 Lux Meter	25
Table 3.3 Power Analyzer	25
Table 3.4 Power Analyzer	26
Table 4.1 Break down of Annual Energy Cost 2014/2015	28
Table 4.2 Incomer Power Parameters	30
Table 4.3 Energy Bill Break down for one year	31
Table 4.4 (a) Light Pipe specifications	34
Table 4.4 (b) Basement Illumination Levels	35
Table 4.5 International illumination Standards	36
Table 4.6 Basement Lighting load	36
Table 4.7 Existing FTL in EFC	37
Table 4.8 Lighting fixtures installed in EFC	38
Table 4.9 LED Brightness	40
Table 4.10 LEDs used to Replace FTL in EFC	40
Table 4.11 LED Lumen	40
Table 4.12 Energy savings by use of LEDs Lighting fixtures	41
Table 4.13 Solar Energy Potential in Nairobi	42
Table 4.14 Operation of the Energy saving system	48
Table 4.15 Power factor surcharge May 2014 to April 2015	49
Table 4.16 Power factor for Lift 1	51
Table 4.17 Power factor for Lift 2	52

Table 4.18 Water Pumps and their respective power factors-----	52
Table 4.19 Economic Analysis for light pipes-----	55
Table 4.20 Economic Analysis use of LEDs-----	55
Table 4.21 Design parameters for Solar Panel Installation-----	56
Table 4.23 Solar PV Calculator-----	57
Table 4.24 Savings due to Tariff Migration-----	58
Table 4.25 Total Capital Investments and Annual energy Cost savings-----	58

## LIST OF FIGURES

Figure 1.1 a view of Equatorial Fidelity Centre-----	3
Figure 1.2 630KVA Transformer serving Equatorial Fidelity Centre-----	4
Figure 1.3 Variation of Energy Prices in Kenya-----	4
Figure 1.4 Trend of Energy Prices in Kenya-----	5
Figure 2.1 Energy Consumption trend in Rural and Urban areas in Kenya-----	11
Figure 2.2 Typical solar PV Architecture-----	12
Figure 2.3 Major components in Installation of Solar PV-----	13
Figure 2.4 10kW rooftop Solar PV-----	13
Figure 2.5 World standard motor efficiency classification-----	14
Figure 2.6 Motor efficiency graph-----	15
Figure 2.7 Light piping system diagram-----	17
Figure 2.8 Typical Light pipe system-----	18
Figure 2.9 Vertical, Horizontal and parabolic collectors-----	19
Figure 2.10 Cross-section of a parabolic concentrator-----	20
Figure 2.11 Horizontal light pipe for deflected and un-deflected beam-----	21
Figure 2.12 Light extraction from the light pipes-----	23
Figure 2.13 Subterranean train station-----	23
Figure 2.1 Light pipes serving the underground floors-----	23
Figure 3.1 Lux meter, Power logger and clamp meter-----	25
Figure 4.1 Energy cost distribution in EFC-----	28
Figure 4.2 Incomer three phase voltages-----	29
Figure 4.3 Power analysis in the bus bars-----	29
Figure 4.4 Correlation of KVA Demand and Electricity consumption-----	30
Figure 4.5 Light pipe distribution network-----	32
Figure 4.6 Typical look of a Light pipe-----	32
Figure 4.7 Light pipe diffuser in operation-----	33
Figure 4.8 Basement parking area in EFC-----	33
Figure 4.9 Daylight availability in Nairobi-----	34

Figure 4.10 Test performance of a 560mm diameter and 25m in length-----	35
Figure 4.11 Existing fluorescent tubes 18W, 2ft-----	37
Figure 4.12 Lighting load-----	39
Figure 4.13 Graphical representation of daily solar radiation in Nairobi-----	43
Figure 4.14 Observed annual temperature trend in Nairobi 1960- 2008-----	43
Figure 4.15(a) Rooftop of EFC-----	44
Figure 4.15(b) Lighting load profile vs. projected solar PV generation-----	46
Figure 4.16 Energy dispatch saving system-----	46
Figure 4.17 Energy switching system in operation-----	47
Figure 4.18(a) Power factor analysis-----	49
Figure 4.18(b) Power factor vector diagram-----	50
Figure 4.19 Main incomer logged power factor-----	50
Figure 4.20 Logged power factor for Lift 1-----	51
Figure 4.22 Water pumps energy consumption evaluation-----	52
Figure 5.1 Depletion of Fossil fuels-----	61

## LIST OF ABBREVIATIONS

<b>EFC</b>	Equatorial Fidelity Centre
<b>EMO</b>	Energy Management Opportunities
<b>BEC</b>	Building Energy Codes.
<b>CO2</b>	Carbon Dioxide
<b>KVA</b>	Kilovolt Amperes
<b>KWh</b>	Kilowatt hours
<b>GHG</b>	Green House Gases
<b>IEA</b>	International Energy Agency
<b>REA</b>	Rural Electrification Authority
<b>IPCC</b>	International Panel on Climate Change
<b>KPLC</b>	Kenya Power Limited Company.
<b>KETRACO</b>	Kenya Transmission Company
<b>O&amp;M</b>	Operation and maintenance record
<b>PV</b>	Photovoltaic
<b>PSH</b>	Peak Sun Hours
<b>LED</b>	Light Emitting Diode
<b>IEA</b>	International Energy Agency
<b>AVG</b>	Average
<b>MAX</b>	Maximum
<b>Eqn</b>	Equation
<b>IEC</b>	International Electro technical Commission for rotating machinery
<b>PF</b>	Power factor

## **Abstract**

The demand for energy keeps rising which requires the generation of vast amount of electricity. Changes have been made to make buildings more energy efficient. Understanding the use of energy in buildings requires an insight into the amounts of energy consumed and the different types of fuels used.

The objective of this dissertation was to identify energy saving potential in commercial buildings in Nairobi outlining measures that would yield energy savings. A case study was done in Equatorial Fidelity Centre (EFC) located in Westlands along Waiyaki way in Nairobi. Improving energy efficiency can deliver a range of benefits to the economy and society at large. In this study the main objective was to identify energy saving opportunities to lower the annual energy bill in EFC which has been escalating since 2011 amounting to Kshs. 8,042,771.0 and Kshs. 12,682,248.0 in 2015. Therefore an audit was carried out to identify potential areas for energy savings improvement and hence lower energy bill.

In addition economic evaluation was performed to determine economic viability of the implementation of energy savings opportunities identified. The economic assessment captured technical implementation aspect of all measures outlined and finally a simple payback period was performed to appraise the implementation of potential measures that would yield energy savings.

Five major areas were identified that would potentially lower energy bill in EFC namely; Use of Light pipes in the basement to supplement artificial lighting, Use of Roof top Solar PV for Lighting load, replacement of existing Fluorescent tube with LEDs, Power factor Improvement and Tariff Migration. All these measures were found to contribute in lowering energy consumption and hence lowering energy bill. Annual cost saving was found to be Kshs. 4,010,663.93 with a payback period of 3 years and 1 month.

# CHAPTER ONE: INTRODUCTION

## 1.1 Introduction and Background

Energy is the main drive for development in all Industrialized and developing countries. Energy as a source in its various natural forms is getting depleted or is inadequate. With increase of technology, energy use is ever increasing and the demand in some countries is outstripping supply.

The Petroleum product and electricity are the main sources of energy, their prices are ever increasing. The petroleum costs have increased drastically worldwide within the last ten years to an ever high cost of 140US\$ per barrel in 2014. The increase in Petrol prices affects the cost of electrical energy in that the cost of fuel is transferred to the customers as a fuel cost charge

The major objective of conducting an energy audit for a building is to find out how efficiently energy is being used in the building, and to identify opportunities for improvement .This requires an evaluation of the amount of energy used by various systems and equipment in the building over the audit period. Unfortunately, provision of metering devices for monitoring energy consumption in buildings in Kenya is in general rather limited. Besides the KPLC meters, you may have few sub-meters, or no sub-meters. For such buildings, only aggregate energy consumption data would be obtainable e.g. from electricity bills, which cover a large group of equipment. As a result, the energy efficiency of individual system or equipment would have to be assessed on the basis of estimated energy consumption.

Energy efficiency factors in buildings vary according to geographical position, climate, building type and location. The distinction between developed and developing countries is important, as is the contrast between retrofitting existing buildings and new construction. In all cases there are different standards of building quality. It is vital that energy efficiency permeates all levels and is not restricted to high end properties.

Energy auditing, while conceptually understood, is a relatively recent phenomenon in Kenya. In fact, energy audits are now mandatory for large commercial and industrial facilities – and a certificate is awarded by the Energy Regulatory Commission. Typically, an energy audit should be carried out after every three years.

ERC classifies energy consumers into 3 major category

**Table 1.1: Category of Energy Consumers**

Low	Medium	High
< 180,000kWh	<1,200,000kWh	>1,200,000kWh

**Source: ERC 2014 Report**

As shown in table 1.1 above, low energy consumers are facilities whose energy requirements fall below 180,000 kWh annually. Medium energy consumers are classified as facilities whose annual energy consumption averages between 180,000 kWh and 1,200,000 kWh annually.

Facilities demanding 1,200,000 kWh and above annually are categorized as large energy consumers.

Therefore ERC requires that all consumers beyond 180,000kWh annually i.e. consumers in the category of high and medium, should be audited to evaluate how efficiently energy is being used and to identify measures for improvement, but a lot of emphasis has been put in Manufacturing Industries leaving Commercial buildings.

In addition with respect to high cost of energy related to over-reliance on fossil fuel powered plants, several technologies have been put up to harness renewable energies which include use of solar PV to tap solar energy and use of Light pipes to tap outdoor sunlight and channel it to the interior of the buildings during daytime which would lower the cost of production.

#### **1.1.1 Equatorial Fidelity Centre (EFC)**

EFC is a commercial building located in Westland, Nairobi and houses major commercial offices which include ECO-Bank, Equatorial insurance firm, African oil, Trademark center among others. The building comprises of 6 floors together with a mezzanine, basement and parking. It has 1 basement floor for parking. All tenants are billed centrally at the Power Control Centre using one KPLC Meter. The tenants are sub-metered by management and billed according to their consumption. Electrical Energy is the major component of Energy used in this building. The major energy consuming equipment are Lighting Systems, Air Conditioners, Water Pumps and Lifts.



**Fig 1.1: A view of Equatorial Fidelity Centre**

Figure 1.1 shows a front view of Equatorial Fidelity Centre where a case study was carried out and it consumes energy ranging from 600,000kWh to 800,000kWh annually with an average energy cost ranging from Kshs 8 Million to Kshs.13 Million respectively.

**Table 1.2 Baseline Information for EFC**


<b>Annual Electricity Consumption</b>	<b>637,407 kWh</b>
Annual Electrical energy cost	Kshs. 12,682,248 million per annum
Average Maximum Demand	150 KVA
Average Electrical Energy Cost	Kshs 19.93 per kWh
Demand Charge	800/KVA
Annual Occupancy	75,000 Occupants

EFC receives power from KPLC at 11KV and stepped down to 415V 3phase 4 wire system by a step down transformer rated 630KVA. In addition a standby generator rated 500KVA is installed and is used during power outage from the grid to take up the full load.



**Figure 1.2: 630KVA Transformer serving Equatorial Fidelity Centre**

Figure 1.3 shows energy cost variation for the year 2014/2015 which was a period of consideration in this study.



**Figure 1.3: Variation of Energy Prices**

Source: KPLC records


### 1.2 Problem Statement

EFC uses Electricity and Diesel for its energy requirements. Electricity takes the highest percentage between the two. Electricity bill incurred in EFC has continued to escalate, increasing by 33% percent from 2011/2012 to 2014/2015 with annual energy consumption of 587,258.7kWh and 637,407 kWh respectively. Table 1.3 below shows the breakdown of annual energy consumption and their respective energy bill from 2011 to 2015.

**Table 1.3: Historical Energy Consumption in EFC**

YEAR	Consumption (kWh)	Accrued Cost(Kshs)	Energy
May 2011- April 2012	587,258.7	8,042,771.0	
May 2012- April 2013	612,235.6	8,265,558.30	
May 2013 – April 2014	621, 872.2	9,887,228.4	
May 2014 – April 2015	637,407.0	12, 682,248.0	

This indicates that there is a need to bring down energy bill which would in turn lead to low cost of production hence bring competitiveness of the services in the market. From Figure 1.4 it is evident that the escalation of energy surcharges in Kenya has been on the rise.



**Figure 1.4: Trend of Energy Prices in Kenya from 2009 to 2015**

**Source: ERC Records**

The aim of this research is therefore to carry out an energy audit for EFC and identify energy saving opportunities that would lower energy consumption and in turn lower associated energy cost.

### 1.3 Research Objectives

The main objective of this study is to identify energy saving opportunities that would contribute in lowering energy cost.

The specific objectives are:

- i. Carry out an energy audit and Identify Opportunities of energy savings

- ii. Assess use of Light-pipes in the basement (Parking area) during daytime as an addition saving measure
- iii. Assess use of rooftop Solar PV for the lighting systems and design of a control system switching between Gen set, mains and solar PV
- iv. Carry out an Economic Evaluation of all Identified energy saving opportunities and Payback Period

## **CHAPTER 2: LITERATURE REVIEW.**

### **2.1 Energy Savings**

Even in the context of an enlarged view of the potential outcomes of energy efficiency improvements, the role of energy savings as the primary objective of energy efficiency policy remains unchanged. Reducing energy consumption will remain a goal of energy ministries and well-targeted policies as the best way to achieve energy conservation.

Energy efficiency can produce energy savings at all levels; individual, sectoral, national and international and the impacts of those energy savings can trickle through to generate wider socioeconomic outcomes. If the actual savings delivered by an energy efficiency measure turn out to be lower than predicted, this is often considered to undermine the success of the intervention. In these cases, policy evaluators should investigate why lower than expected energy savings have been achieved, and consider how implementation could be adjusted to capture more energy savings but it is also important to consider what other benefits may have resulted from the measure. It may be that additional energy consumption can be explained as a consequence of achieving those other benefits.

While some multiple benefits can be seen as a result of energy savings and should be counted in addition to energy savings achieved, others can occur independently of energy savings and could provide a different measure of success of energy efficiency programs, to be considered where energy savings are low. Policy-makers should consider any such trade-off between reduced energy savings and socioeconomic welfare gains arising from particular energy efficiency measure and how the balance should be struck between energy savings and other benefits in designing energy efficiency policy.

One advantage of energy efficiency actions compared with other measures is the rapidity with which results are produced. For this reason, energy efficiency is often cited as one of the best near-term options to reduce energy demand and greenhouse gas emissions. An improvement in technical efficiency can have immediate effect on energy consumption and, especially in the case of smaller projects, can be relatively quick to be put in place.

This is an important feature of energy efficiency improvements as society considers which measures are likely to deliver the benefits needed at different moments in time. The short-term

outcomes possible through energy efficiency improvements are crucial in helping solve problems facing policy makers such as sudden changes in unemployment, energy supply, energy affordability to name a few. Energy efficiency improvements in other areas can provide longer-term outcomes such as national competitiveness, reduced public health costs, and energy security that ensure economic sustainability for the future.

## **2.2: Electricity Prices and Pricing Structure in Kenya.**

ERC was established under the Energy Act, 2006 as the energy sector regulatory agency, with responsibility for economic and technical regulation of power, renewable energy and downstream petroleum sub-sectors. This mandate includes tariff setting and review, licensing, enforcement of standards, dispute settlement and approval of power purchase and network service contracts.

The existing retail tariffs were approved by the then Electricity Regulatory Board (ERB) in June 1999 and came into force on 1<sup>st</sup> August 1999 simultaneously with the Interim Power Purchase Agreement (IPPA) between KenGen and Kenya Power and Lighting Company which set the base bulk tariff at 2.36 Kshs/kWh.

The retail tariffs were rebalanced in May 2000 to mitigate the impact of drought but, there has been no other increase in the base non-fuel tariffs since August 1999.

Since 1999, several power industry parameters have changed including but not limited to significant increases in the power purchase costs as a result of inflation adjustment clauses inbuilt into the Power Purchase Agreements between Independent Power Producers (IPPs) and KPLC which have financially exposed KPLC over the years. Power purchase costs from new and upcoming power generation projects, as well as the costs of transmission and distribution projects intended to meet growing power demand have resulted in increased revenue requirements.

The 2016 effective power capacity in the country stood at about 2000 MW (including 146 MW of emergency plants) against a growing peak demand of about 1500 MW. The reserve of margin in 2016 excluding the IPP is about 6% against an international benchmark of 15% for systems of similar size.

There are several power generation projects planned and committed to come on stream in the next four years. These projects involve the development of over 600 MW in new power generation capacity.

### 2.2.1 Consumer Categories in Kenya

Table 2.1 below shows several consumer categories effected from 1<sup>st</sup> December 2013

**Table 2.1 Summary of Proposed Retail Tariffs.**

CUSTOMER CATEGORY		Unit Cost			PROPOSED RATES			
Code	Customer Type	Charge Method	Unit Cost	Existing Rate	2012/2013	2013/2014	2014/2015	2015/2016
DC	Domestic	Fixed	KSh/month	120	200	250	250	300
SC	Small Commercial	Energy	KSh/kWh	2.00	5.10	5.10	5.75	5.75
		Energy	KSh/kWh	8.10	11.40	11.90	12.30	12.30
		Energy	KSh/kWh	18.57	19.30	23.36	23.86	23.86
		Fixed	KSh/month	120	200	250	250	250
CI1	Commercial/Industrial	Energy	KSh/kWh	8.96	13.66	14.55	15.00	15.00
		Fixed	KSh/month	800	2,000	2,200	2,200	2,500
CI2	Comm/ Industrial	Energy	KSh/kWh	5.75	9.75	10.80	11.60	13.00
		Demand	KSh/kVA	6,00	800	800	800	800
		Fixed	KSh/month	2,500	4,000	4,000	5,000	5,000
		Energy	KSh/kWh	4.73	7.95	7.95	10.30	10.30
CI3	Comm/ Industrial	Demand	KSh/kVA	400	520	520	520	520
		Fixed	KSh/month	2,900	4,500	5,000	5,000	6,000
		Energy	KSh/kWh	4.49	7.35	8.15	8.35	9.35
C14	Comm/ Industrial	Demand	KSh/kVA	200	270	270	270	270
		Fixed	KSh/month	4,200	6000	6500	6500	7,000
		Energy	KSh/kWh	4.25	7.05	7.80	8.00	9.05
C15	Comm/ Industrial	Demand	KSh/kVA	170	220	220	220	220
		Fixed	KSh/month	11,000	16,000	17,000	17000	18,000
		Energy	KSh/month	4.10	6.90	7.70	7.90	8.90
		Demand	KSh/KVA	170	220	220	220	220
IT	Interruptible	Fixed	KSh/month	120	200	250	250	300
		Energy	KSh/kWh	4.85	13.50	14.50	14.50	16.60
DC		Fixed						
IT								
SC								
IT								
SL	Street Lighting	Fixed	KSh/month	120	200	250	250	300

Table 2.1 shows five major tariffs in Kenya with their respective charges effected from December 1<sup>st</sup> 2013.

Table 2.2 shows the summary of surcharges which are subjected to all tariffs in Kenya,


**Table 2.2: Surcharges applied on all tariffs.**

Surcharge	Rate / Notes
Fuel Cost Charge (FCC)	Variable rate per kWh, published monthly by KPLC in the Kenya Gazette (but not on their website!). It is reflective of the cost (to KPLC) of generating electricity during the previous month.
Foreign Exchange Rate Fluctuation Adjustment (FERFA)	Variable rate per kWh, published monthly by KPLC. This includes the sum of the foreign currency costs incurred by KenGen, sum of the foreign currency costs incurred by KPLC other than those costs relating to Electric Power Producer, and the sum of the foreign currency costs incurred by KenGen.
Inflation Adjustment (IA)	Variable rate per kWh, published monthly by KPLC. Factors include the Underlying Consumer Price Index as posted by Kenya National Bureau of Statistics and the Consumer Prices Index for all urban consumers (CPI - U) for the US city average for all items 1982 - 84 as published by the United States Department of Labor Statistics. We are not certain why the cost of Kenyan electricity depends on how much folks in the USA are spending.
WARMA Levy	Variable rate per kWh, published monthly by KPLC. It is determined from the amount of energy supplied from hydroelectric facilities in the previous month.
ERC Levy	3 cents per kWh
REP Levy	5% of the base rate
Power Factor Surcharge	A surcharge applied if the consumer's power factor falls below 0.9. The surcharge applied is 2% of the base rate and the demand charge for every 1 per cent by which the Power Factor is below 0.9.
VAT	16% on everything except the WARMA, ERC and REP levies (Prior to 2 September 2013, consumption less than 200kWh was excluded from VAT, and VAT was charged at 12%. These concessions were removed in the VAT Act 2013.)

**Table 2.3: Energy Demand in Kenya**

Years	2006/07	2007/08	2008/09	2009/10	2010/11	2011/12	2012/13
<b>URBAN</b>							
<b>Annual Consumption</b>	1,113	1,255	1,254	1,290	1,424	1,531	1670
<b>Off Peak</b>	50	74	43	36	38	31	18
<b>No. Of Customers</b>	791,282	899,029	1,061,911	1,212,583	1,444,061	1,655,994	1,877,418
<b>Average Consumption (kWh)</b>	1,470	1,478	1,221	1,094	1,012	944	899
<b>Share of Urban Consumption (%)</b>	83%	84%	83%	82%	82%	83%	80%
<b>RURAL</b>							
<b>Annual Consumption</b>	221	240	250	279	307	340	406
<b>No. of Customers</b>	133,047	161,354	205,287	251,056	309,287	382,631	453,544
<b>Average Consumption(kWh)</b>	1,661	1,487	1,218	1,111	993	805	895
<b>Share of Rural Consumption (%)</b>	17%	16%	17%	18%	18%	17%	20%
<b>Countrywide</b>							
<b>Annual Consumption</b>	1,334	1,495	1,504	1,569	1,731	1,828	2072
<b>No. of Customers</b>	924,329	1,060,383	1,267,198	1,463,639	1,753,348	2,038,625	2,330,962
<b>Average Consumption(kWh)</b>	1,443	1,410	1,187	1,072	987	897	891

Source: KPLC Annual Accounts and Statistics.




**Fig 2.1: Energy Consumption trend in Urban and Rural Areas**  
Source: KPLC Records

It is a clear indication from the above figure 2.1 that the demand for electricity has been on the rise and at a steady rate, both in urban and in rural areas in Kenya.

### 2.3 Solar Photovoltaic for Commercial Buildings

Photovoltaic cells can be utilized individually for small applications, however when more power is needed a number of cells are put together to form a module, and modules can also be grouped together to form arrays. In theory arrays can range from a small number of modules to power a building to thousands of modules to power a town.



**Fig 2.2: Typical Solar PV System Architecture**

PV is a flexible building material. It can be used for roofs, curtain walls, decorative screens can be embedded in glazing, and can also directly replace other conventional materials in the building fabric. These products can serve the same structural and weather protection purposes as their traditional alternatives, as well as offering the benefit of power generation. PV generates approximately 100 kWh/m<sup>2</sup> depending on the type of PV and system efficiency.

PV arrays can be integrated into the roofs and walls of commercial, institutional and industrial buildings, replacing some the usual wall cladding or roofing materials and minimizing the costs of PV systems.

Commercial and industrial buildings are normally occupied during daylight hours which correlate with the availability of solar radiation. Therefore the power generated via the PV systems can theoretically minimize the need to purchase power from the grid at the standard commercial tariffs. In other words it is economically feasible to use as much onsite PV power as possible utilities; this technology is mostly used in countries such as Germany, Netherlands and Japan.

The PV system begins with the roof-mounted modules, which use semiconductors to convert solar energy into direct current (DC) electricity. Within the building inverters are then used to convert DC power into the form of alternating current (AC). Compatible with standard building

devices, the energy enters the Main Distribution Panel. The panel distributes energy to various parts of the building.



**Fig 2.3: Major components in Installation of solar PV**



**Fig 2.4: A 10kW rooftop solar PV, Western District police station- US**

## **2.4 Electrical Systems in Commercial Buildings**

For most commercial buildings and a large number of industrial facilities, the electrical energy cost constitutes the dominant part of the utility bill. Lighting, office equipment, and motors are the electrical systems that consume the major part of energy in commercial and industrial buildings.


- a) **Lighting.** Lighting for a typical office building represents on average 40% of the total electrical energy use. There are a variety of simple and inexpensive measures to improve the efficiency of lighting systems. These measures include the use of energy efficient lighting lamps and ballasts, the addition of reflective devices, delamping (when the luminance levels are above the recommended levels by the standards), and the use of daylighting controls.

Most lighting measures are especially cost-effective for office buildings for which payback periods are less than one year.


- b) **Motors.** The energy cost to operate electric motors can be a significant part of the operating budget of any commercial and industrial building. Measures to reduce the energy cost of using motors include reducing operating time (turning off unnecessary equipment), optimizing motor systems, and using controls to match motor output with demand, using variable speed drives for air and water distribution, and installing energy-efficient motors.

In addition to the reduction in the total facility electrical energy use, retrofits of the electrical systems decrease space cooling loads and therefore further reduce the electrical energy use in the building. These cooling energy reductions as well as possible increases in thermal energy use (for space heating) should be accounted for when evaluating the cost-effectiveness of improvements in lighting and office equipment.

Figure 2.5 and 2.6 below shows graphical representations of the comparison of the efficiencies of standard efficiency motors with high efficiency motors under the IEC 60034-30:2008 standards



**Figure 2.5: World standard motor efficiency classification**



**Figure 2.6: Motor Efficiencies graph**

- IE1 Standard Efficiency Motor
- IE2 High Efficiency Motor

A sample calculation is shown below for a replacement of a standard efficiency induction motor with a high efficiency induction motor are shown overleaf

## 2.5 Day lighting and Illumination in Commercial Buildings

### 2.5.1 Daylight and energy in Buildings.

The use of natural light in buildings has many implications for the energy use in buildings. A reduction in the energy consumption of a commercial building can be achieved by decreasing the need for, or use of artificial light. Natural light is more efficient than electrical light, by providing more light for less heat than artificial light. For example, at a given level of illumination, a tungsten light produces between 5 and 14 times more heat than a daylight (Bake and Steemers, 2000). As a consequence, daylight also lowers the cooling requirements of a building up to 15% (Muhs, 2000)

Up to 75-80% of electric lighting consumption could be saved through the use of advanced daylighting technologies and improved integration of day lighting systems with efficient artificial lighting and effective lighting controls, when compared to conventional buildings (Kristensen, 1994, Hayman et al., 2000). In addition, as the greatest consumption of electricity in commercial

buildings peaks in the middle of the day when there is also greatest abundance of natural light, the possibilities for energy savings via the use of day lighting are considerable (Muhs, 2000)

Introduction of natural light into buildings is normally achieved through simple apertures in the envelope such as windows or skylights. Side lighting from windows in the buildings decreases rapidly with distance from the window, passively reaching inwards only up to 4 to 6m passive zone. Therefore, a disproportionate amount of daylight must be introduced into the front of the room to achieve small gains in daylight levels at the back of the space (Beltran et al., 1997). Generally spaces at distances further than the passive zones require artificial lighting for illumination. Top lighting (From skylights) is a very good solution to obtain good daylight distribution levels in the space, as long as the ceiling apertures are well designed and do not let direct sunlight in. It is also good for the building that has good plan.

Consequently to attain a good distribution of daylight into the interior of a building, the building plan is limited to having floor plates with depths less than 8 to 10m and should have high ceilings. However, these design limitations have only been applied in European countries (Baker and Steemers 2000); in other places like Australia, Asia, and United States of America, deep plan buildings have become a common practice in modern office design.

### **2.5.2: Innovative Daylight Systems**

Innovative daylight systems are optical devices capable of bringing natural light further into the interior zones of large buildings than is possible with simple day lighting strategies such as windows or skylights. There are two major groups of innovative daylighting devices, light guiding systems and light transport systems.

#### **2.5.2.1 Light transport system**

Is used to collect and transport sunlight over long distances within a building, and are usually referred as Light pipes or light guides. Light transport system generally have three elements


- i. A collection head which tracks sunlight or simply redirects it inside the pipe
- ii. The pipe itself that transports the light to where it is needed. This is dependent on the material selected for the pipe (i.e. lenses, mirrored lights, Prismatic pipes and solid core systems)

- iii. A distribution system that include extractor devices, which extracts light from the pipe to the exterior, and diffusers that spread light uniformly across the space

There are two major systems of innovative daylighting devices, Lighting guiding systems and light transport systems. Lighting guiding systems although very efficient in redirecting natural light deeper into the room usually reach distances up to 10 meters, and therefore, light transport systems are required when the core of the building is more than 10 meters from the window.

### 2.5.3 Typical Light Transport Systems

For deep plan buildings, with, greater than 10M from the window, natural illumination can only be practically achieved by light transport systems. Light transport or remote source systems are devices capable of channeling sunlight to areas in buildings that receive inadequate natural lighting and usually remote from the building envelop. These systems consists of three major components. 1) Light collection; 2) Light Transportation 3) light distribution: Extraction and emissions




**Figure 2.7: Light piping system diagram**

A variety of light transport systems have been investigated, built and tested for numerous building projects, and many studies have shown their beneficial use (Tsangrassoulis et al., 2005, Aizenberg, et al., 2003, Audin, 1995, Ayers and Carter, 1995, Bennett and Eijadi, 1980). In addition to the general benefits of daylighting, benefits of light piping systems include:


- i. The possibility of a centralized building lighting system that pipes natural light and artificial light to distribution devices replacing electrical cabling and fixtures

- ii. Elimination or reduction of infrared or ultra violet radiation from sunlight, although further study is required to quantify this reduction, particularly for Ultra violet radiation
- iii. The extraction of desired fractions of the light along the pipe as required
- iv. Producing a uniform distribution of light in the space from a small concentrated output



**Fig 2.8: Typical Light-pipe system**

Light-guiding systems send direct and diffuse sunlight to the interior of the room without the secondary effects of glare and overheating. There are several different systems and they have similarities in their general performance, position in the building, or means of directing the light. They can be grouped as follows



**Figure 2.9: A) Vertical element, B) Horizontal element C) Parabolic collectors**

**Vertical elements-** This group includes devices that are usually placed in the top of the windows vertical or with some angle of inclination. They redirect the light deeper into the room by means of reflection and refraction

**Horizontal Elements-** This group includes devices formed by one horizontal baffle (e.g. light shelves, sun scoops), or systems form by multiple horizontal or sloping slats. Their most important benefit is their protection against glare, but they have problems with dust accumulation, and therefore require maintenance. These systems can redirect sunlight to the back of the room, depending on their position.

**Parabolic Collectors:** The principle behind these devices is a compound parabolic collector. A specific geometric form internally covered with reflectance material accepts light from a specified angular range of the sky, and light is then redirected deeper into the room.

## 2.5.4 Light Collection for light transport systems.

Collection systems generally consist of reflective or refracting devices. Their main objective is to capture sunlight and direct it through a small aperture into the interior. Collecting and conveying day a specific location can be achieved by active or passive systems (Audin, 1995).


Light collection is achieved either by redirection of sunlight by, for example, flat mirrors, or by concentration of light. Concentration describes the increase of illumination on a surface above the incident solar level. Concentration is achieved by geometrical optics (Imaging or non-imaging optics) of the collector or by fluorescent systems (Smestad et al., 1990). Following is a brief description of passive and active light collection systems, which includes either concentration or redirection systems.

### 2.5.4.1 Passive Collection systems

A passive collection system implies no mobile parts. Passive collectors have a single orientation and are fixed during installation to maximize redirection down shaft-way. A fixed system requires a larger area for light collection to compensate for the lack of a tracking system which can improve sun collection efficiency during the day and year. Consequently, passive collectors results in larger transport components that can use considerable floor area. Performance increases are therefore correlated with increasing size of the system components i.e. collection and transmission. These include:

### 2.5.4.2 Luminescent Solar Concentrators (LSC)

This is another system designed to concentrate sunlight. It consists of a thin plate of a highly transparent material e.g. polymethyl methacrylate-PMMA, that is doped with fluorescent dyes. The dye molecules absorb part of the solar radiation incident on the plate and re-emit fluorescent radiation that is transported to the edges of the plate by total internal reflection.



**Fig 2.10: Cross-section of a fluorescent concentrator.**

**Source: Zastrow (1986)**


The collectors generally consist of plates 120mm width, 2mm height and 1m to 2m long to provide sufficient area to supply enough output light, about 1000 lumens, for a standard domestic room size. Mirrors added along base and edges of the LSC collector redirect any rays that may have not been absorbed by any of the panels back towards the panels, improving the overall efficiency of the collector.

#### 2.5.4.2 (A) Light redirection collectors

In contrast to the light concentration collector systems, light redirection systems operate on aligning sunlight with the light transport system. The efficiency of light transportation in light pipes depends on the angle at which sunlight enters the light pipe. Sun rays that reach the input aperture of a light pipe with an angle closest to that of pipe orientation will undergo fewer reflections, thereby a collector system that redirects the sun rays more axially along a pipe will increase the performance of the system. Consequently designs of passive collector systems have focused primarily on improving the incidence of the sun angle reaching the aperture of the sun pipe.

#### 2.5.4.2 (B) Light Transmission

The transmission of light through the pipe is given by  $T = \rho^N$ , where  $\rho$  the reflectance of the surface of the light pipe and N is the number of reflections along the pipe which bring light to the point of interest.



**Figure 2.11: transmission of light through horizontal pipes for the deflected and undeflected beam of light at different times of the day**

In the present application the input apertures of the pipes are on the western façade and sunlight enters the apertures from 12 noon through the afternoon as illustrated in figure 2.10. It is from

this illustration that the transmission of the light through pipes depends in a fairly complicated way, on the sun elevation angle and, therefore, on time of day.

### 2.5.5 Efficiency of Light Pipe

The earliest work on the transmission of mirrored light pipe tube seems to be theoretical calculation given by (Zastrow, 2001) gave a simple formulation to relate the transmittance of a mirror light pipe tube to its surface reflectance ( $\rho$ ), the angle between the incident light and the tube's axis ( $\theta$ ), the length of the tube (L), and the effective diameter of the tube (deff)

$$T = \rho^{L \cdot \tan\theta / \text{deff}} \dots\dots\dots (2. 1)$$

Where T is the transmittance, i.e. the ratio of the amount of light transmitted to the incident light (Swift et al, 1999) gave an equation to describe the transmission of collimating light within mirrored light pipe. The equation is


$$T = (4 / \pi) \int_{s=0}^1 [s^2 / (1 - s^2)^{1/2}] R^{\text{int}(p \tan\theta / s)} \times \{1 - (1 - R)[p \tan\theta / s - \text{int}(p \tan\theta / s)]\} ds \dots\dots (2.2)$$

Where T is the transmittance of the light pipe tube, i.e. the ratio of the amount of transmitted light to that of incident light, R is the reflectance of the interior surface of the light pipe tube, P is the aspect ratio of the light pipe,  $\theta$  is the angle between the incident light and the light tube axis, int is the integer function, that is int (a) is the integer less than or equal to a.

### 2.5.6 Light Extraction


As the light traverses the pipe especially mirrored light pipes a certain proportion of light must be extracted at intervals along the light pipe to illuminate several floors for a vertical light pipe to illuminate several floors for a vertical light pipe, or a uniform distribution across a space for horizontal light pipes.

A principle of a light extraction system was developed by Edmonds et al. (1997a) and illustrated in the figure below. In this example the same amount of light is extracted at each aperture. To achieve this, the first extractor panel is made sufficiently reflecting to deflect one quarter of the light. The second deflects one third of the remaining light. More complicated ratios may be derived to account for transmission loss in the pipe that occurs between each extractor



**Fig 2.12: Light extraction in the light pipes**

Figure 2.13 and 2.14 shows successful implementation of light pipes in commercial buildings in Berlin Germany and Turkey



**Fig 2.13: Subterranean Train station at Potsdamer Platz, Berlin**



**Fig 2.14: Light pipe serving four under-ground floors**

**Source: Borusan group building in Istanbul, Turkey**

## **CHAPTER 3: METHODOLOGY**

### **3.1 Technical Energy Audit Evaluation**

A preliminary discussion was held with senior executives to firm up the operations to be evaluated during the General energy audit. The management was looking for measures that could make a significant mark in energy costs especially electricity. Measurements were done on all major equipment.

It was followed by a survey of the building which was done to identify the types of energy being used, the quantity and energy consumption of all fixed electrical equipment except the standard general office equipment and personal computers for staffs.

Measurements were then conducted by use of portable instruments which included the Power Analyzer, Lux meter and data logger. Specifications of equipment and operating data were collected to assess efficiency and performance of various systems. Discussions with plant personnel, during the energy audit, helped improve understanding operations, various measures already taken and future plans.

#### **3.1.1 Equipment used for Measurements**

During the audit specialized equipment were used in logging and measuring various readings. Below is a table detailing some of the equipment and their use.

**Table 3.1: Measurements Tools**

Tools	Description
Lux Meter	Measures illumination levels. Used to study lighting at particular locations
Power Data Logger and Analyzer	Measures and logs data such as voltages, currents, phase angles, harmonic distortions, and power factors
Clamp Meter	Measures voltages, currents and resistance
Lux Sensors	Measuring outdoor lighting Lux levels.



Lux Meter



Power Logger



Clamp Meter

**Figure 3.1: Lux meter, Power Logger and Clamp Meter**

Instruments of high precision were used in taking all measurements. The following table 3.2, 3.3 and 3.4 shows the various instrument used with their respective accuracies which was verified by KEBS and met the minimum threshold to carry out a research.

**Table 3.2: Lux meter**

Equipment Accuracy	
CA 830 Lux Meter	
Incandescent Lamp	$\pm 3 \% + 10$ counts
Other Sources	$\pm 11\% + 2$ counts

**Table 3.3: Power Analyzer**

CA 8435 Power Analyzer	
Voltage Range	10.00 to 1,000 V AC/DC
Current Probe	30A to 10,000 AAC (Typical accuracy 1%)
Frequency Range	40Hz to 69Hz
Harmonics	THD, orders 0 to 50 per phase
Sample	256 samples / period

**Table 3.4: Power Analyzer**

PEL 103 Power Analyzer	
Voltage Range	10.00 to 1,000 V AC/DC / $\pm 0.2\%$ + 0.5 V
Current Probe	200.0 mA to 10.00 kA AC / $\pm 1.2\%$ + 70 mA
Frequency Range	DC, 50 Hz, 60 Hz & 400Hz

### 3.1.2 Historical Data

The energy consumption and production levels for the building were obtained from their records for the period under consideration, May 2014 – April 2015. The electrical energy consumption data was obtained from the electricity bills for EFC for the same period. The diesel fuel data was obtained from the fueling cards record and consumption level records for the same period. The generator capacity was obtained from the name plate. In addition summary data for Energy bills from 2010 to 2015 was provided by the property management company Knight Frank to determine energy trend.

### 3.2 Assessment of the use of Light pipes in the basement of EFC

In this assessment the illumination level in the basement due to artificial lighting were first measured by use of six lux meters placed at different locations to evaluate the effectiveness of light-pipes use in the parking area that would offer the same illumination. Data was recorded and uploaded for analysis. In addition the number and size of the light pipes required was evaluated for implementation.

### 3.3 Assessment of the use of Solar PV on the roof of EFC

Solar energy was studied to evaluate the number of solar panels that could meet the demand for the lighting systems of the whole building which could be used during daytime.

Data from National Meteorological department was obtained specifically showing the climatic conditions in Nairobi and its environs for a period of one year which was used in evaluation of potential of solar energy that could be tapped by the use of solar panel for the lighting system in EFC.

The rooftop of EFC was assessed to determine the area available and the capacity of solar panel installation that it could support and with the help of Civil Structures Engineer, the structural strength of the roof was as well assessed and the building exposure to sunlight was evaluated to determine the amount of light that directly strikes on the rooftop in a day.

In addition an Energy saving System was designed using at mega 328 microcontroller, TIP 122 transistors, potentiometer, ceramic and electrolytic capacitors, inductor, 16 MHz crystal clock, LEDs, LM358 op Amp and relays. Simulation was done using Proteus2008 for the purpose of trial testing and demonstrating that control systems could play part in maximizing the available solar energy for the lighting system and as well alarming in case of replacement of more energy consuming electrical appliances. It was designed in such a way that if the amount of solar energy available would be enough to meet the demand for all the six floors, it would cut out on the mains up to the point where it could not meet the demand for at least one floor whereby the whole lighting system would now be fed from mains directly.

## CHAPTER 4: RESULTS AND ANALYSIS

### 4.1 INTRODUCTION

#### 4.1.1 Energy Sources at EFC

EFC has the following Energy sources in use


- i. Electricity
- ii. Diesel Fuel

Electrical energy is the primary source of energy at EFC. A diesel generator rated 630kVA is on standby for use when the primary source is not available. Sometimes, electricity can be interrupted when the utility has a planned outage for maintenance or new customer connection and sometimes interruptions could be caused by faults which trip the feeder and an alternative feeder may not be available to back feed. During these interruptions the generator should be able to take on the full load of the building, it uses diesel oil for its operation. Table 4.1 shows annual energy cost from both Utility bill and for Diesel used

**Table 4.1: Break down of Annual Energy Cost 2014/2015**

Energy Resource	Kshs
Utility Bill	12,682,248
Diesel	1,152,000
<b>Total</b>	<b>13,834,248</b>


Figure 4.1 below illustrates the percentage of energy cost distribution for electricity and fuel as a source of energy



**Figure 4.1 Energy Cost distribution in EFC (Electricity vs. Diesel)**

### 4.1.2 KPLC Main Incomer

Figure 4.2 below shows the incomer voltages as recorded by the power logger in EFC.



4.2: Incomer Voltages




Fig 4.3: Power analysis from the bus bars

**Table 4.2: Incomer power parameters obtained from the Power Logger**

Parameter	L1	L2	L3
Avg Current	175.6	149.5	159
Max Current	346.9	374	270.1
Avg Voltage (LN)	232.9	230.2	231.3
Max Voltage (LN)	246.1	243.8	244.5
Avg Voltage (LL)	400.1	400.7	402
Max Voltage (LL)	423.3	423.9	424.6
Power factor	0.88	0.91	0.87

Table 4.1 above show details of incoming power, i.e. Voltages, Current and power Factor for all the phases as displayed by the power logger.



**Figure 4.4: Correlation of Electricity Consumption and KVA Demand –May 2014 -April 2015**

Figure 4.4 above shows the variation of energy consumption in 2014/2015 as well as variation of Maximum demand in the same period. It shows that a lot of energy was consumed in June 2014 and least energy consumed in July the same year and the highest Peak Demand was experienced in the month of July 2014.

#### 4.1 Historical Information

A survey was first carried out to determine the existing energy consumption so that the energy savings opportunities could be identified as well as the assessment of rooftop solar PV and Light transport system in terms of size and capacity as an additional energy saving opportunities. Historical data for energy consumption was obtained for a period of one year as shown on table 4.3 below.

**Table 4.3 Energy Bill Analysis for a Period of one year**

<b>Equatorial Fidelity Centre - Electricity Consumption</b>									
Month	Occupancy	Energy Consumption Total (KWh)	Maximum Demand (kVA)	Maximum Demand Charges (Kshs)	Power Factor	Total Monthly Bill (Kshs)	Kshs/kWh	Specific Energy consumption kWh/Occupant	Power Factor Surcharge
May-14	6,250	49,995	144	115,200	0.88	972,458	19.45	8.00	19,261
Jun-14	6,250	65,619	154	123,200	0.93	1,418,989	21.62	10.50	-
Jul-14	6,250	39,851	133	106,400	0.92	940,956	23.61	6.38	-
Aug-14	6,250	54,504	141	112,800	0.86	1,246,320	22.87	8.72	55,088
Sep-14	6,250	54,818	145	116,000	0.94	1,153,431	21.04	8.77	-
Oct-14	6,250	52,075	153	122,400	0.88	1,058,038	20.32	8.33	19,076
Nov-14	6,250	56,726	164	131,200	0.91	1,067,602	18.82	9.08	-
Dec-14	6,250	51,133	149	119,200	0.95	929,845	18.18	8.18	-
Jan-15	6,250	53,697	156	124,800	0.83	955,362	17.79	8.59	75,088
Feb-15	6,250	54,514	160	128,000	0.92	1,099,044	20.16	8.72	-
Mar-15	6,250	50,001	159	127,200	0.93	894,392	17.89	8.00	-
Apr-15	6,250	54,474	144	115,200	0.89	945,811	17.36	8.72	18,242
<b>Average</b>	<b>6,250</b>	<b>53,117</b>	<b>150</b>	<b>120,133</b>	<b>0.89</b>	<b>1,056,854</b>	<b>19.93</b>	<b>8.50</b>	-
<b>Annual</b>	<b>75,000</b>	<b>637,407</b>	<b>1802</b>	<b>1,441,600</b>		<b>12,682,248</b>	<b>239</b>		<b>186,755</b>


As shown in Table 4.3 above, annual energy cost amounted to Kshs. 12,682,248.00 between May 2014 and April 2015 with an annual Maximum KVA Demand averaging to 150 KVA.

In addition it shows that the building doesn't perform to the expectations in terms of power factor which averages to 0.89 and hence severally penalized by KPLC since it slightly falls below the required minimum of 0.9.

## 4.2. IDENTIFIED ENERGY SAVING OPPORTUNITIES

### 4.2.1 ENERGY SAVINGS BY USE OF LIGHT PIPE IN THE BASEMENT.

Technology has been developed to use light pipes to channel outdoor light into the interior of the building, this helps in saving energy from the artificial lighting during daytime, in this study basement was considered for assessment because it wasn't exposed to outdoor lighting leaving artificial lights in use for 24 hours a day. Figure below shows a sample of a successful implementation of a parking area using Light pipes.



**Figure 4.5: Light pipe Distribution Network**

**Source: Parking area in University of Central Florida.**

Figure 4.5 above shows how light distribution is done, where inlet transport light pipes are directed to one main light pipe to enable uniformly distribution of light from one source.




**Figure 4.6: Typical look of a light pipe**

**Source: Steam plant Ltd, Kenya.**

Figure 4.6 shows a typical dome that is used in tapping sunlight rays and concentrating them into the tube and is wrapped inside with aluminum foil for high reflectivity. The dome is made of polycarbonate material which has properties that help in blocking light rays with temperatures beyond 28.5 degrees and redirect them during morning and evening times when illumination

intensity is a bit low. This helps in optimizing temperature as well as keeping the room illuminated both in the morning and in the evening hours.



External appearance of Light Pipe and a Diffuser




Diffuser emitting light

**Figure 4.7: Light pipe diffuser in operation**

**Source: Steam-Plant Ltd, Kiambu, Kenya.**


Figure 4.9 above was obtained from one of the rooms being illuminated by use of light pipes in Kiambu County, and they were installed by steam Plant Company as a pilot project for demonstration. Figure 4.8 below shows the EFC parking area with lights on. Its size was determined.



Basement Parking Area, EFC

**Figure 4.8: Basement parking area, EFC**

EFC is located in the epicenter of Nairobi region which has a relatively high potential for outdoor illumination levels that would favor the implementation of light pipes in commercial buildings. Figure 4.9 shows different peaks of illumination for March, August and December with values of 80000, 70000 and 60000 lux respectively. In a year, therefore enough sunlight could be tapped for use in the basement to supplement artificial lighting during daytime.



**Figure 4.9: Daylight availability in Nairobi**


**Source: Kenya Meteorological Department**

During this evaluation, the building height of EFC was measured and found to be 22.5m from the ceiling of the basement to the rooftop where light tapping would occur. Therefore the most preferred light pipe in this study was as shown in table 4.4 a below.

**Table 4.4 (a): Light Pipe Specifications, Source Solartube UK.**

No.	Model (Solartube)	Tube Size (Diameter)	EDCS (Effective Daylight Capture Surface)	Light Coverage Area	Potential tube Length
1	160 DS	250mm	1032cm <sup>2</sup>	14-19m <sup>2</sup>	9m+
2	290 DS	350mm	1871cm <sup>2</sup>	23-28m <sup>2</sup>	16m+
3	310 DS	560mm	2150cm <sup>2</sup>	32-38m <sup>2</sup>	25m+

The highlighted model of the solar tube (Light pipe) was considered in this study for use in the basements since it meets the required specifications.



**Figure 4.10: Test performance for a 560mm Diameter, 25M Length light pipe**  
**Source: Solartube, UK**

From figure 4.10 above, it can be shown that internal illumination by use of this light pipe i.e. 560mm diameter and 25m length can reach to levels of 300 lux, this test was carried out by Solartube UK company to determine efficiency of light pipes when subjected to different lengths. In this study, it was observed that the lux levels required to meet the existing levels were found to be an average of 159 as shown in table 4.4.

Assessment of the existing illumination levels for the basement were first measured and recorded by use of six lux meters placed at different locations in the basement and tabulated as shown in table 4.4 b so that the evaluation and sizing of the light pipes could be determined.

**Table 4.4 (b): Basement Illumination Levels.**

Lux Meters	Lux
L1	161
L2	155
L3	160
L4	153
L5	158
L6	172
Total	959
<b>Average</b>	<b>159</b>

International standards requires that lux levels for the parking area should be in a range of 120 - 200 Lux (IEA, 2012) as shown in table 4.5 below and therefore an optimal lux level of 150 was considered to obtain the optimum illumination.

**Table 4.5: International Illumination Standards (IEA, 2012)**

Activity	Illumination (lux, lumen/m <sup>2</sup> )
Public areas with dark surroundings	20 – 50
Simple orientation for short visits	50 – 100
Working areas where visual tasks are only occasionally performed	100 – 120
Warehouses, Homes, Theaters, Archives, Parking	120-200
Easy Office Work, Classes	250
Normal Office Work, PC Work, Study Library	500

Total Illuminated area by the existing artificial lighting system in the basement was found to be 640m<sup>2</sup> and therefore the evaluation of the number of light pipes required was based on the size of the parking area, and the expected energy savings to be offset by this implementation was based on lighting load in the parking area as shown in table 4.6

**Table 4.6: Basement lighting load**

SR. NO.	DESCRIPTION	LAMP TYPE	QTY	CHOKE(9W)	RATED WATT PER FIXTURE(W)	Total Wattage
1	Parking area	2 X 36W Fluorescent	40	9	72	3600
2		1 X 36W Fluorescent	1	9	36	45
3		38W CFL	1	0	38	38
	<b>Total Power</b>					<b>3683</b>

a) Total operating hours for the lighting system in the basement = **24 hours per day**

b) Expected effective operating hours for the Light pipes= **10 hours,**

c) Number of days considered in a year was =**250**

d) Annual Expected Energy savings.  $3.683 \times 10 \times 250 = \mathbf{9,2075kWh.}$

Therefore use of light pipes would yield energy savings amounting to 9,2075kWh annually.

#### **4.2.2 .USE OF LEDs TO REPLACE EXISTING FLUORESCENT TUBE LAMPS.**

The total lighting system of the plant was reviewed during the audit. The lighting fixtures in use were observed to be mostly fluorescent tube lamps (FTL) rated at 36W, 18W respectively and

Compact Fluorescent Lamps. All the FTL tubes within the building were generally fitted with electromagnetic (Copper) ballast. Other fixtures found were halogen lamps for outdoor lighting

Table 4.7 below shows the type of the existing lighting fixtures with their respective electronic ballast power ratings.

**Table 4.7: Existing FTL in EFC**

Type of Lamp	Electromagnetic copper ballast(kW)	Total Power Consumed by the Fixture (kW)
36W Tube light, 4Ft	9	45
18W Tube light, 2Ft	9	27




**Figure 4.11: Existing Fluorescent tubes- 18W, 2ft**

Figure 4.11 shows a sample of the existing FTL fixture T8, 2ft and 18 W.

In addition table 4.8 below shows a summary of the existing lighting fixture with their respective power ratings.

**Table 4.8: Lighting fixtures installed in EFC.**

SR. NO.	DESCRIPTION	LAMP TYPE	QTY	RATED WATT PER FIXTURE(W)	Power Rating (W)
1	Parking	2 X 36W Fluorescent	40	72	2880
2	//	1 X 36W Fluorescent	1	36	36
3	//	38W CFL	1	38	38
4	6th Floor	1 X 36W Fluorescent	12	36	432
5	5th Floor(Fidelity Insurance)	4 X 18W Fluorescent	30	72	2160
6	//	2 X 18W CFL	23	18	414
7	ECB	15W LED	40	15	600
8	//	4 X 18W Fluorescent	6	72	432
9	//	2 X 18W CFL	28	18	504
10	4th Floor( Fidelity Insurance)	4 X 18W Fluorescent	34	72	2448
11	//	1 X 36W Fluorescent	12	36	432
12	//	2 X 18W CFL	18	36	648
13	DANONE Nutricia	18W CFL	35	18	630
14	//	12W LED	13	12	156
15	3rd Floor(Fidelity Insurance)	4 X 18W Fluorescent	34	72	2448
16	//	1 X 36W Fluorescent	6	36	216
17	//	2 X 18W CFL	18	36	648
18	Trademark	4 X 18W Fluorescent	40	72	2880
19	//	2 X 18W CFL	20	36	720
20	2nd Floor(Trademark)	4 X 18W Fluorescent	91	72	6552
21	//	2 X 18W CFL	57	36	2052
22	//	50W Halogen	24	50	1200
23	//	100W Halogen	4	100	400
24	1st Floor(Africa Oil)	2 X 18W CFL	50	36	1800
25	//	15W LED	7	15	105
26	//	4 X 18W Fluorescent	46	72	3312
27	ECB	4 X 18W Fluorescent	33	72	2376
28	//	2 X 18W CFL	10	36	360
29	Mezzanine	4 X 18W Fluorescent	73	72	5256
30	//	1 X 36W Fluorescent	10	36	360
31	//	2 X 18W CFL	18	36	648
32	Ground Floor	4 X 18W Fluorescent	27	72	1944
33	//	2 X 18W CFL	18	36	648
34	Basement(ECB IT)	4 X 18W Fluorescent	18	72	1296
35	//	2 X 18W CFL	11	36	396
36	SENATOR	4 X 18W Fluorescent	30	72	2160
37	//	2 X 18W CFL	6	36	216
<b>Total</b>					<b>49803.00</b>



**Figure 4.12: Lighting Load**

Figure 4.12 above shows the split of the lighting load with second floor having the largest share and sixth floor with the least share of the total Lighting load.

LED lamps were considered to replace the existing FTL to yield energy savings. Designers have been using LEDs to substitute various standard fixtures that are used in commercial spaces. For example 18 Watt LED lamps have significantly substituted 36 Watt fluorescent tube light fixture with an additional choke of 9W; the power saving potential is about 30 Watts per fixture.

Therefore an alternative option in saving energy in lighting would be to replace the Fluorescent Lamps with an equivalent LED Lamps. The description of the type of equivalent replacements and savings expected along with is shown in Table 4.12 in page 41.

Light produced by LEDs provides good color rendering and offer the benefit of greater optical control so that the light can be directed to the locations intended. LED fixture efficiencies are 80 to 90% compared to conventional lights which have fixture efficiencies of 40 to 60%.

Higher efficiencies indicate that more light reaches the source and light trespass is minimized. Additionally they do not require strike time and on/off cycling does not affect LED lifetime.

Table below 4.9 and 4.10 below shows the recommended LEDs to replace FTL.

**Table 4.9: LED Brightness**

<b>LED Watts</b>	<b>Lumens (Brightness)</b>
4 – 5	450
6 – 8	1285
9 – 13	1750
16 – 20	2850
25 – 28	3150

**Table 4.10: LEDs used to replace FTL in EFC**

<b>Type (FTL)</b>	<b>Lumens (Brightness)</b>	<b>Equivalent LED</b>
T12 40W 4ft	2900	T12 21 W 4ft
T8 36 W 4ft	2700	T8 18 W 4ft
T5 28W 4ft	2750	T5 15 W 4ft
T8 18W 2ft	1750	T8 10 W 2ft
T5 14W 2ft	1275	T5 8 W 2ft

As highlighted from table 4.10, shows the existing fluorescent tubes and their respective equivalent LEDs considered for replacement.

Table 4.11 below shows the comparison between LEDs and fluorescent tubes of the same size in terms of efficiency. It indicates that LEDs are far more energy efficient than their counterpart fluorescent tubes and therefore they were identified as one of the major energy saving opportunity in EFC.

**Table 4.11: LED Lumen**

<b>Type</b>	<b>Efficiency</b>
T-8 LED Tube light	110-120 lumens per watt
Regular Fluorescent T-8 Tube light	60-80 lumens per watt (lower for one with electromagnetic ballast)

**Table 4.12: Energy savings by use of LED Lighting fixtures**

SR. NO.	DESCRIPTION	Recommendation	QTY	Annual Energy consumption for FTL with Magnetic ballast(9W) kWh	Annual Energy consumption with LED kWh	Expected annual Energy savings kWh
1	Parking	Replace 36W Fluorescent tube lights with an equivalent 18W LED	41	6,457.5	2,583	3,874.5
2	6th Floor	Replace 36W Fluorescent tube lights with an equivalent 18W LED	12	1,350	540	810
3	Fidelity Insurance	Replace 18W Fluorescent tube lights with an equivalent 10W LED	98	23,520	9,800	13,720
		Replace 36W Fluorescent tube lights with an equivalent 18W LED	12	1,350	540	810
4	Trademark	Replace 18W Fluorescent tube lights with an equivalent 10W LED	131	31,440	13,100	18,340
5	ECB	Replace 18W Fluorescent tube lights with an equivalent 10W LED	91	21,840	9,100	12,740
6	Africa Oil	Replace 18W Fluorescent tube lights with an equivalent 10W LED	46	11,040	4,600	6,440
7	Mezzanine	Replace 18W Fluorescent tube lights with an equivalent 10W LED	73	17,520	7,300	10,220
		Replace 36W Fluorescent tube lights with an equivalent 18W LED	10	1,125	450	675
8	Ground Floor	Replace 18W Fluorescent tube lights with an equivalent 10W LED	27	6,480	2,700	3,780
9	Senator	Replace 18W Fluorescent tube lights with an equivalent 10W LED	30	7,200	3,000	4,200
			<b>570.00</b>	<b>138,633.00</b>	<b>53,792.2</b>	<b>81,195.80</b>

As shown in table 4.12, use of LED in EFC would result to an annual energy savings of 81,195 kWh with an annual energy consumption of 53,792.20 kWh. Time of operation for the lighting system was considered to be 10 hours per day except that of the parking which operates 24 hours. As discussed earlier on, Parking had been assessed for use of light pipe during day time for 10 hours in average and therefore during this evaluation use of LEDs in the parking was subjected to the remaining 14 hours a day.

### 4.2.3. ENERGY SAVINGS THROUGH SOLAR PV

#### 4.2.3.1 Potential for Solar PV Power generation for Lighting.


In this study the solar PV was considered for the lighting system during daytime. The evaluation of the solar energy capacity was based on the recommended LEDs lighting load. Solar radiation data for Nairobi was obtained and used in the assessment of potential solar energy generation. Table 4.13 shows the monthly solar insolation data for Nairobi in a year.

**Table 4.13: Solar Energy potential in Nairobi City**

Month	Temperature	Daily radiation horizontal kWh/m <sup>2</sup> /d	solar – tilted kWh/m <sup>2</sup> /d
January	24.2	5.85	5.40
February	25.6	6.14	4.95
March	20.8	5.81	3.86
April	24.3	5.01	2.71
May	23.5	4.59	2.07
June	19.1	4.11	1.80
July	16.9	3.79	1.83
August	17.2	3.96	2.18
September	18.5	4.93	3.09
October	22.7	5.34	4.07
November	22.6	5.08	4.47
December	24.2	5.54	5.27
<b>Annual</b>	<b>21.6</b>	<b>5.01</b>	<b>3.47</b>


**Source: NASA Surface Meteorology and Solar Energy, 2013 Global Data sets averaged for 30 years from 1983-2013.**

Nairobi has high insolation rate with an average of 5-7 peak sunshine hours i.e. the equivalent number of hours per day when solar irradiance is 1000W/m<sup>2</sup> and receives an average daily Insolation of 4- 6 kWh/m<sup>2</sup>. This gives a good platform for harvesting solar energy by use of solar panels. Figure 4.13 below depicts the monthly variation of solar insolation. High solar radiation is experienced in January and least experienced in July.



**Figure 4.13: Graphical representation of Daily solar radiation in Nairobi**

Source: Kenya Meteorological department



**Figure 4.14: Observed annual temperature trends for Nairobi 1960-2008**

Source: Kenya Meteorological department 2013 Report


Figure 4.14 shows that Nairobi has been experiencing rise in temperatures for the past five decades, this in turn provides a good platform for tapping solar energy. It shows that current temperatures in Nairobi is given by;

$T = 0.011X + 3.373$ , substituting Year 2016 in this equation,

$T = 0.01(2016) + 3.73 = 23.89^{\circ}\text{C}$ . This indicates that Nairobi has an average room temperature of  $23.89^{\circ}\text{C}$ .

In this study monocrystalline solar panels were considered for assessment for the lighting load, leaving other loads in the building being fed from the utility. Therefore an evaluation of rooftop solar PV was based on the lighting load for LEDs which was 21.5 kW and addition 10% was considered in the design to allow load stability due to losses leading to a total capacity of 23.6kW solar PV plant.

Figure 4.15 (a) below shows the rooftop of EFC where solar panels would be installed, It clearly shows that the rooftop is well exposed to solar radiation giving room for solar energy potential.



**Figure 4.15 (a): Rooftop of EFC**

#### **Baseline Information**

*Total Area of the rooftop= 750M<sup>2</sup>*


*Design lighting load = Lighting Load by LEDs + 10% losses*

*Daily Peak Sun Hours in Nairobi= 5.74*

*Therefore Lighting load= (53792.2)/ (10×250) = 21.5kW+ 2.1kW= 23.6kW*

Therefore Annual Expected Energy savings is = **42,614kWh** as depicted from table 4.23

Figure 4.15 (b) below shows a graphical representation of data logged for existing lighting load and then extrapolated for the prospected lighting LEDs load profile vs. the prospected Solar PV generation. Data was extracted from data logger and using excel a load profile vs. Solar PV generation was obtained.



**Figure 4.15 (b): Lighting load Profile vs. Projected Solar PV Generation**

It depicts that prospected Solar PV generation will cater for the lighting load during daytime with a peak load of 26kW mostly occurring during mid-day. In addition lighting load profile shows that lighting systems are mostly switched on during daytime with an average load of 24kW and low during night time with an average load of 14kW which is prospected to be fed from mains.

#### 4.2.3.2 Energy Dispatch and Saving System

Energy dispatch and saving system was designed and a hardware was built to demonstrate how solar energy could be maximised in the building for all six floors such that, when the level of solar energy goes down and unable to take the full lighting load, the extra load would therefore be cut off from the solar energy source to the mains source. This would continue to a point where solar energy would not be enough to meet the lighting load for atleast one floor and therefore power from the mains would take on the full electrical load of the building.


This was done by the use of microcontrollers, high speed switching relays, current sensor and LEDs and for the purpose of demonstration only the three floors were considered. In addition the system was designed to limit energy consumption beyond a certain limit, so that in case any lighting fixture is replaced and tends to consume more energy than the previous fixture it triggers an alarm and displays through LCD to the client that the fixture replaced consumes more energy for action.

In this design process three power adapters 12V 2A were used to represent the following sources;

- i. Solar energy- Variable DC power Supply
- ii. Diesel Generator

### iii. Mains from Utility

This system was designed mostly to dispatch energy efficiently among the three sources. It was designed in such way that solar energy would only feed the lighting system and other loads should be fed directly from the mains unless in cases where there is power outage from the mains and therefore the automatic change-over would automatically switch to generator mode for the stand-by generator to take care of the power outage.




**Figure 4.16: Energy dispatch and Saving system**

Three LEDs arrays represent the lighting systems in three floors

LCD Display- Displays the type of energy in use in the three floors.

The three 12V, 2A adapters represent the three sources of power and that one for solar being connected to a potentiometer for variation.

Motor represent loads being fed directly from the mains.



**Figure 4.17: Energy saving system in operation**

Figure 4.17 shows the display from the LCD that, Floor 1, 2, 3 and the motor are all powered by the Standby Generator. This is a situation whereby in case there is no power from mains and from solar as well Generator should take on the full load.

**Table 4.14: Operation of the Energy saving system**

1. Solar Energy Available	No. of Floors	2. Lighting load being fed by Mains	No of Floors	3. Source-Generator Set	No. of Floors fed by Generator
100%	3	Nil	0	OFF	0
70%	2	30%	1	OFF	0
40%	1	60%	2	OFF	0
30%	0	100%	3	OFF	0
30%	0	(Power outage)	0	ON	3
Finally if there is Power outage from mains and solar energy available is > 30% therefore Generator should take over from the mains					

#### **4.2.4 POWER FACTOR IMPROVEMENT.**

From the data collected of the energy bill statement, It showed that the building has an average power factor of 0.89 which slightly falls below KPLC set standards, five out of twelve months fell below power factor of 0.9 which led to power factor surcharges amounting to Kshs.186,755.00. Low power factor is caused by inductive loads such as transformers, electric motors, and high intensity discharge lighting. Unlike resistive loads that create heat by consuming kilowatt, inductive loads require the current to create a magnetic field, and the magnetic field produces the desired work. The total apparent power required by an inductive device is a composite of the following:

- i. Real power – measured in kilowatts, KW
- ii. Reactive power, the nonworking power caused by the magnetizing current, required to operate the device – measured in kilovars, kVar.


The reactive power required by inductive loads increases the amount of apparent power in the distribution system. The increase in reactive and apparent power causes the power factor to decrease. The power factor surcharge incurred in 2014/2015 as per the energy bill is shown in table 4.15

**Table 4.15: Power Factor Surcharge May/2014- April 2015**


Month	Power factor Surcharge (Kshs.)
April/2014	19,261.00
August/2014	55,088.00
October/2014	19,076.00
Jan/2015	75,088.00
April/2015	18,242.00
Total	186,755.00

A power factor surcharge is applied if the consumer’s power factor falls below 0.9 and the surcharge applied is 2% of the base rate and the demand charge for every 1% by which the power factor is below 0.9.

Figure 4.18 (a) shows the power factor trend during the period of consideration i.e. May 2014/ April 2015. It indicates that low power factor was experienced in several months and was below the required minimum value of 0.9 by KPLC and this resulted to power factor surcharges in several months which amounted to Kshs. 186,755.00



**Figure 4.18 (a): Power factor Analysis**



**Figure 4.18 (b): Power Factor Vector diagram**


Improving Power factor lowers reactive power and apparent leading to low energy cost.

$$PF = \frac{kW}{kVA} = \cos$$

Using the Pythagoras rule:


$$\text{Real Power (kW)} = PF \times \text{KVA}$$

Figure 4.19 below shows the logged power factor from the bus bars. It shows the variation of power factor in different times of the day and clearly indicates that in some instances the power factor was as low as 0.8, which was way much below the required minimum threshold of 0.9.



**Figure 4.19: Main Incomer logged Power Factor.**


Power factor for two lifts were obtained by use of power logger. Figure 4.20 and Table 4.16 shows the power factor variation for Lift 1 and aggregate power factor respectively as recorded by the power logger. The same was repeated for the second lift and Data obtained was uploaded and tabulated as shown in figure 4.21 and Table 4.17 respectively. From the two graphical representations for power factor they indicate that at some point power factor was far much below 0.9



**Figure 4.20: Logged power factor for Lift 1**

**Table 4.16: Power Factor for Lift 1**

Red Phase	Yellow Phase	Blue Phase
0.813	0.843	0.842



**Figure 4.21: Logged Power Factor for Lift 2.**

**Table 4.17: Power Factor for Lift 2**

Red Phase	Yellow Phase	Blue Phase
0.881	0.901	0.843

#### 4.2.4.1 Power Factor for water Pumps.

EFC has a total of four water pumps installed, two of them rated 3kW each and the other two rated 5kW each. The four pumps were evaluated in terms of power factor status and data obtained was tabulated as shown in Table 4.18.



Figure 4.22 Water Pumps, energy consumption evaluation

Table 4.18: Water Pumps and their respective power factor

No.	Equipment	Rated kW	Voltage V	Current A	P.F	Frequency Hz
1	Water Pump 1	3	423	3.9	0.88	50
	// 2	3	423	6.9	0.89	50
2	Water Pump 3	5	423	12	0.62	50
	// 4	5	423	11.5	0.74	50

These water pumps were found to have very low power factor that mostly contributed to the aggregate low power factor in the building. All the four pumps suffered from low power factor with values of 0.88, 0.89, 0.62 and 0.74 respectively. These values were as well far much below the utility provider requirements of 0.9.

#### 4.2.4.2 Power Factor Correction.

To improve power factor, a Capacitor bank is required to correct the low power factor which is mostly due to inductive electrical appliances installed in the plant.

From the audited equipment, it was found that the low power factor was majorly contributed by the two lifts and the water pumps installed. This contributed mostly to the power factor surcharges amounting to Kshs.186, 755.00 annually and therefore the required capacitor bank was computed as shown below.

$$\text{Average KVA Demand} = 150 \text{-----} (4.1)$$

$$\begin{array}{l} \text{Average Power Factor} = 0.89 \\ \text{Real Power} = 150 \times 0.89 = 133.5 \text{ kW} \end{array}$$

$$\text{Cos } \theta = 133.5/150 = 0.89$$

Therefore  $\theta = 27.1$  degrees

$$\text{Existing capacitor bank} = 150 \text{ Sin } 27.1 = 68.33 \text{ KVAR} \text{-----} (4.2)$$

Raising Power Factor to 0.99 will lower both power factor surcharge and Maximum KVA Demand charges.

$$\text{I.e. New Cos } \theta = 0.99$$

Therefore  $\theta = 8.10$  degrees

Since Real Power is constant

$$\text{New Apparent Power} = 133.5/0.99 = 135 \text{ KVA} \text{-----} (4.3)$$

$$\text{Capacitor bank} = 135 \text{ sin } 8.1 = 19.1 \text{ KVAR} \text{-----} (4.4)$$

$$\text{KVA Demand Improvement} = \text{Eqn 1} - \text{Eqn 3} = 150 - 135 = 15 \text{ KVA}$$

$$\text{Capacitor Bank required} = \text{Eqn 2} - \text{Eqn 4} = 68.33 - 19.1 = 49.23 \text{ KVAR.}$$

Therefore to raise the power factor to 0.99, a capacitor bank of 49.23 KVAR is required and yields additional advantage of lowering the apparent power by **15KVA**

#### 4.2.5: TARIFF MIGRATION

EFC can consider tariff migration from Commercial/Industrial 1 to Commercial/Industrial 2, as this shall yield cost saving. The two tariffs have different rates as shown below.

##### COMMERCIAL/INDUSTRIAL (CI) - METHOD CI

This tariff is applicable to Commercial and Industrial Consumers for Supply provided and metered by the Company at 415 volts three phase four wire and whose consumption exceeds 15,000 units per post-paid billing period.

- a) A fixed charge of Kshs. 2,000.00

- b) Energy charge of Kshs. 8.70 per unit consumed.
- c) Demand charge of Kshs. 800.00 per kVA.

**COMMERCIAL/INDUSTRIAL (C12) - METHOD C12**

Applicable to Commercial and Industrial Consumers for supply provided and metered by the company at 11,000 volts, per post-paid billing period.

- a) A fixed charge of Kshs. 4,500.00
- b) Energy charge of Kshs. 7.50 per unit consumed.
- c) Demand charge of Kshs. 520 per kVA

From the data above, it shows that tariff CI2 is more favorable since its' Energy and Demand charges are relatively cheaper in comparison to CI1.

Expected cost savings

Energy charge  $8.70 - 7.50 =$  Kshs. 1.20 per unit Consumed.

Demand Charge  $800 - 520 =$  Kshs. 280 per Maximum KVA Demand

On the other hand, fixed charge is relatively lower for CI1 tariff than CI2 with  $4500 - 2000 =$  Kshs. 2,500 but doesn't outweigh the average cost savings due to tariff CI2. These computations excludes other state levies which include Fuel Cost, REA Levy and WARMA among others,

**4.3 ECONOMIC EVALUATION**

**4.3.1 Economic Evaluation: Use of Light Pipes**

Light pipe considered in this case was found to have the following specifications.

- i. Diameter = 560mm
- ii. Length = 25M
- iii. 99.7% Spectral reflectivity
- iv. Diffuser capacity = Illumination area coverage of 36m<sup>2</sup>
- v. Luminance levels = 150 to 200 Lux.
- vi. Loss per set is 22%

Table below shows the sizing of different light pipes and their applications

**Number of Light Pipes Required**

- Expected surface area to be illuminated = 640M<sup>2</sup>
- 1 light Pipe can illuminate an area of 36M<sup>2</sup>

Therefore required number of light pipes to illuminate the total parking area is  $640/36 = 17.7$  light pipes.

**Table 4.19: Economic Analysis for Light Pipes**

No. Light Pipe	Diameter Size(mm)	Length (M)	Area Covered(M <sup>2</sup> )	Capital Cost (Kshs)	Installation + Miscellaneous cost (15% capita Cost)	Total Investment	Expected Annual Energy savings(kWh)	Annual cost Savings
1	500	25	36	85,000.00	12,750.00	97,750.00	511.50	10,194.80
18	500	25	648	1,530,000.00	229,500.00	<b>1,759,500.00</b>	<b>9,207.50</b>	<b>183,505.50</b>

Expected annual energy Savings = **9,207.5kWh**

Projected annual Energy Cost savings = **Kshs. 183,505.50**

Capital Investment = **Kshs. 1,759,500.00**

#### 4.3.2 Economic Evaluation: Use of LEDs

Table 4.20 summarizes energy savings incurred by replacing existing FTL with LEDs

**Table 4.20: Economic Analysis: Use of LEDs. (Kshs 6000/ 18W LED, Kshs 3000/10W)**

Sr No.	Description	Recommendations		Quantity	Expected Annual Energy Savings (kWh)	Expected Annual Cost Savings (Kshs)	Expected Investment (Kshs)
		Replacing Fixtures	Existing				
1	Parking	36W FTL	with 18W LED	41	9460.80	188,553.70	246,000.00
2	6th floor	36W FTL	with 18W LED	12	810.00	16,143.30	36,000.00
3	Fidelity Insurance	18W FTL	with 10W LED	98	13,720.00	273,439.60	470,400.00
		36W FTL	with 18W LED	12	810	16,143.30	36,000.00
4	Trademark	18W FTL	with 10W LED	131	18,340.00	365,516.20	628,800.00
5	ECB	18W FTL	with 10W LED	91	12,740.00	253,908.20	436,800.00
6	Africa Oil	18W FTL	with 10W LED	46	6,440.00	128,349.20	220,800.00
7	Mezzanine	18WFTLwith10W LED		73	10,220.00	203,684.60	350,400.00

**Table 4.20 Continued**

		36W FTL with 18W LED	10	675.00	13,452.80	30,000.00
8	Ground floor	18W FTL with 10W LED	27	3,780.00	75,335.40	129,600.00
9	Senator	18W FTL with 10W LED	30	4,200.00	83,706.00	144,000.00
	<b>Total</b>			<b>81,195.80</b>	<b>1,618,232.29</b>	<b>2,722,800.00</b>

From table 4.20;

Annual Energy Savings by use of LEDs = **81,195.80kWh**

Total Annual Energy Cost Savings = **Kshs. 1,618,232.29**

Expected Investment = **Kshs. 2,722,800.00**

#### **4.3.3 Economic Evaluation: Use of Solar PV for Lighting Load.**

Required solar panel is anticipated to take the full lighting load for LEDs during daytime with a capacity of 23.6kW.

Table 4.21 below shows some of the parameters factored in during design of the roof top solar PV. This helps in ensuring efficient design to meet the anticipated load demand.

**Table 4.21: Design Parameters for solar panel installation (Pricing structure borrowed from Negawatt Company based in Nairobi)**

PV System Size	21,500	W
Cable Losses	5	%
Derating Losses	5	%
Peak Sun Hours	5.74	Hours
Average Cost of Electricity	19.93	Kshs/kWh
Single Panel Power rating	250	W
Single Panel Surface Area	2	M <sup>2</sup>
CO2 Emissions	0.3675	KG CO2/kWh

Negawatt Energy Company situated in Kasarani, Nairobi area has been designing roof top Solar PVs for the last one decade. They have wide experience in solar energy and their design criteria was used in this research. Table 5.3 and 5.4 below shows the typical calculator which was used in Pricing and sizing of a 22.6kW solar PV plant which gave data in terms of investment in regards to tapping solar energy, among them, CO2 reduction, annual energy cost savings and payback period.

**Table 4.22: Implementation Cost for Solar PV (Source: Negawatt Energy)**

Cost of System Breakdown	ksh/W	ksh
Solar panels	68	1,536,800
Balance of system	40	904,000
System Control	14	316,400
Transportation	15	339,000
Installation	18	406,800
Taxes	14	316,400
Total	169	3,819,400

Installation cost are evaluated on the basis of per unit of electricity generated.

**Table 4.23: Solar PV Calculator (Source: Negawatt Energy)**

<b>SOLAR PV SYSTEM</b>		
System Size	21.5	kW
PSH	5.74	Hours
Total System losses(cable rating and derating factors)	10	%
Watts per 2m <sup>2</sup> Monocrystalline panel	200	W
Total number of Panels	91	Pcs
Total Rooftop Area Required	180.8	m <sup>2</sup>
Panel Orientation	20degrees	North
Annual Energy Generation	42,614	kWh
Annual CO2 reductions	16	Tons
Initial Investment (Total system Cost)	3,819,400	Kshs.
Annual Cost of Energy savings	849,304	Kshs.

#### 4.3.4 Economic Evaluation: Power Factor Improvement

The required capacitor bank to raise the power factor from 0.89 to 0.99, as shown earlier is **19.1kVAr**.

Expected Energy cost savings = Savings due to power factor Surcharge + Associated Savings due to lowered KVA Demand

$$186,755 + (15 \times 800 \times 12) = \text{Kshs. } 330,755$$

Cost of Capacitor bank per KVAR = Kshs. 32,000 (Installation Cost Inclusive)

Therefore 49.23 KVAR  $49.23 \times 32,000 =$  Kshs. 1,575,360.00

#### 4.3.5 Economic Evaluation: Tariff Migration

As per the quotation from KPLC the cost for tariff Migration from CI1 to CI2 was found to be Kshs. 2,500,000. In addition it was advised that the plant would still use the existing transformer and that major changes would occur in the metering point.

Tariff Migration was considered for the new annual energy consumption with the outlined energy saving opportunities having been factored in.

Energy Considered for tariff migration= Total annual energy consumption – Annual Energy savings

$637,407 - (81,195.8 + 9,207.5 + 42,614) = 504,389.7 \text{ kWh}$

**Table 4.24: Cost savings due to tariff migration**

No.	Tariff	Fixed Charges Kshs.	Cost Per KVA Demand Charge. Kshs.	Cost Per Unit kWh Kshs.	Annual Energy Considered	Total Annual Energy Charges Kshs
1	CI1	2,000.00	800.00	8.70	504,389.7	5,708,190.39
2	CI2	4,500.00	520.00	7.50	504,389.7	4,679,322.75
<b>Tariff (CI1- CI2)</b>						<b>1,028,867.64</b>

Table 4.24 shows cost savings due to tariff migration from CI1 to CI2.

#### 4.4 PAYBACK PERIOD OF THE ENERGY SAVING MEASURES OUTLINED

Table 4.25 below shows a summary of the total capital investment required to implement the outlined energy saving measures in EFC to yield maximum energy savings annually.

**Table 4.25: Total Capital Investment and total Annual Energy cost savings**

	Measures	Annual Energy Cost Saving Kshs.	Capital Investment Kshs.	Payback Period (Years)
1	Use of LEDs	1,618,232.29	2,722,800.00	1.6
	Tariff Migration	1,028,867.64	2,500,000.00	2.4
	Use of Solar PV	849,304.00	3,819,400.00	4.5
	Power factor Improvement	330,755.00	1,575,360.00	4.7
	Use of Light Pipe	183,505.00	1,759,500.00	9.6

**Table 4.25 Continued**

<b>Total</b>	<b>4,010,663.93</b>	<b>12,377,060.00</b>	<b>(3.1 Years)</b>
--------------	---------------------	----------------------	--------------------

If all identified energy saving opportunities were to be implemented, would yield an annual savings amounting to Kshs. 4,010,663.93 with capital investment amounting to Kshs. 12,377,060.00. Therefore Payback period can be computed as = Capital Investment/ Annual savings

$$\text{Payback period} = \frac{\text{Capital cost of installation}}{\text{Annual Savings}}$$

$$= 12,377,060/4,010,663.93$$

$$= 3.1 \text{ years}$$

$$= 3 \text{ years } 1 \text{ month}$$

From the capital investment and annual energy cost savings in this research resulted to a payback period of 3 years and 1 month for all outlined energy saving opportunities. This gives the implementation aspect a sound economic consideration to lower energy bill in EFC.

## **CHAPTER 5: CONCLUSIONS AND RECOMMENDATIONS**

### **5.1 Conclusions**


The main objective of this study was to identify energy savings potential in a commercial building in Nairobi, a case study of Equatorial Fidelity Centre, From the findings reported in this study five major areas were identified as potential areas for energy savings and found to contribute to annual energy cost savings amounting to Kshs. 4,377,663.98. Out of the five major identified energy savings opportunities use of LEDs was found to yield highest energy savings followed by Tariff Migration from CI1 to CI2, use of rooftop solar PV for lighting LEDs, Power factor improvement and finally use of light pipes in the basement.

Energy efficiency measures outlined in this research were found to play a critical role in improving energy savings and associated energy cost. EFC having been set up in 2006 was found to have met several of the building energy savings codes which included energy efficient HVAC, but there were several areas that were found not to have met and needed to be worked on to improve energy savings. Energy efficiency measures are meant to reduce the amount of energy consumed while maintaining or improving the level of comfort in the building.

Economic evaluation was done in a systematic way so that the computation of payback period would be as a result of the total savings accrued from the five measures. Implementation of the above measures would result to a payback period of 3 years and 1 month as earlier shown. This makes the implementation to be economically viable and sound. Use of Light pipe is not common in Africa but it has been successful in several countries in Europe and mostly in United Kingdom. During the assessment of use of light pipes in the parking area, Steam plant Company in Kiambu County was severally visited and much was borrowed from them in terms of sizing and pricing as it is the only company in Kenya offering Light pipes services.

Use of rooftop Solar PV in Commercial buildings in Kenya is not a common phenomenal yet the potential for solar energy is quite high. EFC rooftop was found to be well exposed to outdoor sunlight and had enough surface area for solar panel installation that would meet the lighting load demand. During this research an energy dispatch system was designed and a hardware was built to demonstrate how to maximize usage of solar energy and change over to mains if the available solar energy would not be enough to cater for the lighting load of at least one floor where the full lighting load should be switched to the mains.

The light pipe system will have a great impact to the next generation. The natural resource are not enough to serve the next generation, thus there is a need to introduce some renewable energy to maintain our society. Therefore light pipe system is a great technology to preserve the society to keep developing.



**Figure 5.1: Depletion of Fossil Fuels**

In addition Figure 6.1 shows that the total fossil fuel are decreasing, it indicates that the development of renewable ways to supply human daily activities are very important. Therefore, the sustainable of Light Pipe represent new ways to replace the electricity supply.

Power Factor Improvement was found to contribute 8.2% of the total energy cost savings. This was as a result of inductive loads being installed in the building which includes water pumps and Lifts. Improving power factor would result to;

- i. Lowered utility bill with a higher pf. A low power factor requires an increase in the electric utility's generation and transmission capacity to handle the reactive power component caused by the inductive loads. Ideally the industries are expected to operate with PF ranging from 0.9 to 1.0
- ii. The electrical distribution system's capacity will increase. Uncorrected PF will cause power losses in the distribution system, voltage drops are experienced as power loss increase. Excessive voltage drops can cause overheating and premature failure of motors and other inductive equipment.

Regarding audits and energy saving measures and despite the fact that the measures were discussed at medium-scale level it is evident that they could actually make a substantial energy savings. These savings could reduce the financial burden of the current energy bills at the commercial buildings and factories.

Significant savings can be achieved not through a relatively small number of direct projects but through the stimulation of widespread replication activities across the country since very little emphasis have been put in Commercial buildings and major emphasis being in Industries.

## **5.2 Recommendation: Light pipe**

Further studies should be done towards the assembling of the light pipe and its integration with the other building subsystems. One aspect would be the design of the light pipe towards its industrialization which would involve the use of a more durable material such as metal. This material will have to be able to receive a reflective coating in its interior that will stay flat and will not deteriorate over the time.

Another aspect would be the particular design of the light pipe output to obtain a better integration with the ceiling parts, and the possible introduction of the electric luminaire together in the same assembly.

Of special concern is the integration with electric light using lighting control systems (zoning and dimming controls). For this purpose, the placement of vertical sensors will be useful to evaluate illumination in the vertical plane, since some dimming controls are positioned in that way.

It is also recommended that an energy conservation fund should be set up to assist with financing future energy conservation related investments.

### **5.2.1 Other Recommendations**

- i. The need for a long term commitment from the Government to promote energy efficiency in Commercial buildings.
- ii. Better end-use analysis needs to be undertaken in order to know what progress is being made on improving energy efficiency of buildings
- iii. Certification needs to be implemented in parallel with effective information campaigns to explain to the wider public
- iv. The energy certification programme should be designed to help construct and maintain end-use databases to help in the policy analysis

## 7. REFERENCES

- [1]. Kenya Power and Lighting Company, Electricity Bills, Jan 2008 to Dec 2011
- [2]. Kengen, <http://www.kengen.co.ke/index.php?page=business>, 11-10-2012
- [3]. The Kenya Power and Lighting Company, tariff and Rates, <http://www.kplc.co.ke/index.php?id=45>, 11-10-2012
- [4]. Kurmi, R.S. Steam tables with Mollier diagram, 2006
- [5]. Wikipedia, Lumen, [http://en.wikipedia.org/wiki/ANSI\\_Lumens#](http://en.wikipedia.org/wiki/ANSI_Lumens#), 11.10.2012
- [6]. Eng. Kaburu Mwirichia, Electricity Tarrifs, <http://www.erc.go.ke/erc/tarrifs/electricity> tariff, Gazete Notice no.12, 2006
- [7]. Energy conservation-The Indian experience, Department of power & NPC publications, <http://www.scribd.com/doc/66216531/39/Case-Study,11-10-2012>
- [8].Recipes country info Kenya, <http://www.energyrecipes.org/reports/genericData/Africa/061129>, 11-10-2012
- [9]. Consumers federation of Kenya, <http://www.cofek.co.ke/>, 11-2012
- [10]. G.F.C. Rogers & Y.R. Mayhew, Thermodynamics & Transport Properties of Fluids
- [11]. Gary, J.C, V (2004) Maximizing Energy savings with Enterprise Energy management systems, IEEE Power and Energy, 2004
- [12] Shin, J. Y., Yun, G. Y. and Kim, J. T. 2011. Evaluation of Day lighting Effectiveness and Energy Saving Potentials of Light-Pipe Systems in Buildings. Indoor and Built Environment. 21:129–136.
- [13] Reinhart C. F. and Wienold, J. 2011. The Day lighting Dashboard - A Simulation-Based Design Analysis for Daylight Spaces. Building and Environment. Vol. 46: 386–396.
- [14] Mayhoub, M. S. and Carter, D. J. 2011. The Costs and Benefits of Using Daylight Guidance To Light Office Buildings. Building and Environment. 46: 698–710.
- [15] Romm, J. and Browning, W. D. 1998. Greening the Building and the Bottom Line Increasing Productivity through Energy-Efficient Design. Rocky Mountain Institute, 1–16
- [16] Plympton, P., Conway, S. and Epstein, K. 2000. Day lighting in Schools: Improving Student Performance and Health at a Price Schools Can Afford. American Solar Energy Society Conference.
- [17] Heschong Mahone Group. 1999. Day lighting in Schools An Investigation into the

Relationship between Day lighting and Human Performance. Fair Oaks, CA 95628.

[18] Oakley, G., Riffat, S. and Shao, L. 2000. Daylight Performance of Light pipes. Solar Energy. 69: 89–98.

[19] Building Research Establishment (BRE), Day lighting Design in Architecture

[20] Building Research Establishment (BRE), <http://www.bre.co.uk>

[21] Diana Schumacher, Energy: Crisis or Opportunity?

[22] Donald R. Wulfinghoff, The Modern History of Energy Conservation: An Overview for Information Professionals.

[23]Edward Vine, Drury Crawley, Paul Centolella, Energy Efficiency and the Environment; Forging the link. Washington, D.C: American Council for an Energy Efficient Economy (ACEEE) in cooperation with University wide Energy Research Group, University of California, 1991.

[24] Electric Power Research Institute (EPRI) EM-4195, Energy Management Systems for Commercial Buildings

[25]Energy Efficiency and Renewable Energy Network (EREN), <http://www.environmental-expert.com/articles/article193/article193.htm>

[26]Energy Policy – a Consultative Document, Cmnd 7101, HMSO, London, February 1978, pp. 20, 21.

## **APPENDICES**

### **Appendix 1: Tariffs in Kenya**

There are five main consumer categories:

- i. Domestic Consumers (DC);
- ii. The Small Commercial (SC);
- iii. The Commercial/Industrial (CI),
- iv. The Interruptible (IT) and
- v. The Street Lighting (SL).

#### **DOMESTIC CONSUMER (DC) - METHOD DC**

The DC will be applicable to domestic consumers metered at 240V or 415V and whose energy consumption does not exceed 15,000 kWh per month. The energy charge will be in three steps based on consumption as follows; 0-50kWh; 51-1500kWh and over 1,500 kWh units per postpaid billing period or pre-paid units purchase period.

- a) A fixed Charge of KSH 120.00
- b) Energy Charges of
  - i. Kshs.11.62 per Unit for 51- 1,500 Units consumed;
  - ii. Kshs. 19.57 per Units Consumed above 1,500.

#### **SMALL CONSUMER (SC) - METHOD SC**

Applicable to non- domestic Small Consumers for supply provided and metered at 240 or 415 volts and whose consumption does not exceed 15,000 Units per Postpaid billing period or Pre-paid purchased period.

- d) A fixed Charge of Kshs. 150
- e) Energy Charge of Kshs 12.00 per units for all units consumed.

#### **COMMERCIAL/INDUSTRIAL (CI) - METHOD CI**

Applicable to Commercial and Industrial Consumers for Supply Provided and metered by the Company at 415 volts three phase four wire and whose consumption exceeds 15,000 units per post-paid billing period.

- f) A fixed charge of Kshs. 2,000.00
- g) Energy charge of Kshs. 8.70 per unit consumed.
- h) Demand charge of Kshs. 800.00 per kVA.

### **COMMERCIAL/INDUSTRIAL (C12) - METHOD C12**

Applicable to Commercial and Industrial Consumers for supply provided and metered by the company at 11,000 volts, per post-paid billing period.

- i) A fixed charge of Kshs. 4,500.00
- j) Energy charge of Kshs. 7.50 per unit consumed.
- k) Demand charge of Kshs. 520 per kVA

### **COMMERCIAL/INDUSTRIAL (C13) - METHOD C13**

Applicable to Commercial and Industrial Consumers for supply provided and metered at 33,000 volts, per post-paid billing period.

- a) A fixed charge of Kshs. 5,500.00
- b) Energy charge of Kshs. 7.00 per unit consumed.
- c) Demand charge of Kshs. 270 per kVA

### **COMMERCIAL/INDUSTRIAL (C14) - METHOD C14**

Applicable to Commercial and Industrial consumers for supply provided and metered by the company at 66,000 volts, per post-paid billing period.

- a) A fixed charge of Kshs. 6,500.00
- b) Energy charge of Kshs. 6.80 per unit consumed.
- c) Demand charge of Kshs. 220 per kVA

### **COMMERCIAL/INDUSTRIAL (C15) - METHOD C15**

Applicable to Commercial and Industrial Consumers for supply provided and metered by the company whose consumption does not exceed 15,000 Units per Post-paid billing period.

- d) A fixed charge of Kshs. 17,000.00
- e) Energy charge of Kshs. 6.60 per unit consumed.
- f) Demand charge of Kshs. 220 per kVA

## THE INTERRUPTIBLE- METHOD IT

Interruptible off-peak supply of electrical energy applicable to ordinal y consumers provided and metered by the Company whose consumption metered at 240 or 415 volts and does not exceed 15,000 units per post-paid billing period or pre-paid units purchased period.


- a) A fixed charge of Kshs. 120.00
- b) Energy charge of Kshs. 13.00per unit consumed.


## STREET LIGHTNG- METHOD SL

Applicable to public and county governments metered by the company at 240 or 415 volts per post-paid billing period for supply of electrical energy to public lamps.

- a) A fixed charge of Kshs. 200.00
- b) Energy charge of Kshs. 10.50per unit consumed

## Appendix 2: Microcontroller simulation





### Appendix 3: Programming code for Microntroller

```
#include <LiquidCrystal.h>

LiquidCrystal lcd(10, 4, 3, A2, 1, 0);

int Solar_Relay = 5;

int Mains_Generator_Relay = 8;

int First_Floor_Lighting = 7;

int Second_Floor_Lighting = 13;

int Third_Floor_Lighting = 11;

int motor = 9;

int Solar_Power_Pin = A5;

int Mains_Power_Pin = 6;

int Alarm_Pin = A1;

int Power_Detector = 12;

int Power_Detection_Activator = 2;

int Indicator_Pin = A4;

////////////////////////////////////

int Active = LOW;
```

```

in buttonState;          // the current reading from the input pin
in lastButtonState = LOW; // the previous reading from the input pin

// the following variables are long's because the time, measured in milliseconds,
// will quickly become a bigger number than can be stored in an int.
long lastDebounceTime = 0; // the last time the output pin was toggled
long debounceDelay = 50;  // the debounce time; increase if the output flickers

////////////////////////////////////

void setup()
{
  pinMode(Solar_Relay,OUTPUT);
  pinMode(Mains_Generator_Relay,OUTPUT);
  pinMode(First_Floor_Lighting,OUTPUT);
  pinMode(Second_Floor_Lighting,OUTPUT);
  pinMode(Third_Floor_Lighting,OUTPUT);
  pinMode(motor,OUTPUT);
  pinMode(Mains_Power_Pin,INPUT);
  pinMode(Power_Detector,INPUT);
  pinMode(Alarm_Pin,OUTPUT);

  PinMode(Power_Detection_Activator, INPUT);
  pinMode(Indicator_Pin,OUTPUT);
  lcd.begin(16, 2);
  lcd.print(" ENERGY SAVING ");
  lcd.setCursor(0, 1);
  lcd.print("  SYSTEM  ");
  delay(3000);
  lcd.setCursor(0, 0);

```

```

lcd.print("FL1:  FL2:  ");
lcd.setCursor(0, 1);
lcd.print("FL3:  MOT:  ");
delay(3000);
digitalWrite(Solar_Relay,HIGH);
}
void loop()
{
if( analogRead(Solar_Power_Pin) > 800 )
{
digitalWrite(First_Floor_Lighting,LOW);
digitalWrite(Second_Floor_Lighting,LOW);
digitalWrite(Third_Floor_Lighting,LOW);
if( digitalRead(Power_Detector) == LOW && Active == HIGH )
{
lcd.setCursor(4, 0);
lcd.print("H_P");
analogWrite(Alarm_Pin,1000);
}
else
{
analogWrite(Alarm_Pin,0);
lcd.setCursor(4, 0);
lcd.print("SOL");
}
lcd.setCursor(12, 0);
lcd.print("SOL");
lcd.setCursor(4, 1);
lcd.print("SOL");
}

```

```

delay(1000);
}
else if( (analogRead(Solar_Power_Pin) > 400) && (analogRead(Solar_Power_Pin) < 800) )
{
digitalWrite(First_Floor_Lighting,HIGH);
digitalWrite(Second_Floor_Lighting,HIGH);
if( digitalRead(Mains_Power_Pin) == HIGH )
{
if( digitalRead(Power_Detector) == LOW && Active == HIGH )
{
lcd.setCursor(4, 0);
lcd.print("H_P");
analogWrite(Alarm_Pin,1000);
}
else
{
analogWrite(Alarm_Pin,0);
lcd.setCursor(4, 0);
lcd.print("MAI");
}
}
lcd.setCursor(12, 0);
lcd.print("MAI");
}
else
{
if( digitalRead(Power_Detector) == LOW && Active == HIGH )
{
lcd.setCursor(4, 0);
lcd.print("H_P");
}
}
}

```

```

    analogWrite(Alarm_Pin,1000);
}
else
{
    analogWrite(Alarm_Pin,0);
    lcd.setCursor(4, 0);
    lcd.print("GEN");
}
    lcd.setCursor(12, 0);
    lcd.print("GEN");
}
delay(1000);
}
else
{
    digitalWrite(First_Floor_Lighting,HIGH);
    digitalWrite(Second_Floor_Lighting,HIGH);
    digitalWrite(Third_Floor_Lighting, HIGH);
    If(digitalRead(Mains_Power_Pin) == HIGH )
    {
        if( digitalRead(Power_Detector) == LOW && Active == HIGH )
        {
            lcd.setCursor(4, 0);
            lcd.print("H_P");
            analogWrite(Alarm_Pin,1000);
        }
    }
else
{
    analogWrite(Alarm_Pin,0);
}

```

```

lcd.setCursor(4, 0);
lcd.print("MAI");
}
  lcd.setCursor(12, 0);
  lcd.print("MAI");
  lcd.setCursor(4, 1);
  lcd.print("MAI");
}
else
{
  if( digitalRead(Power_Detector) == LOW && Active == HIGH )
  {
    lcd.setCursor(4, 0);
    lcd.print("H_P");
    analogWrite(Alarm_Pin,1000);
  }
  else
  {
    analogWrite(Alarm_Pin,0);
    lcd.setCursor(4, 0);
    lcd.print("GEN");
  }
  lcd.setCursor(12, 0);
  lcd.print("GEN");
  lcd.setCursor(4, 1);
  lcd.print("GEN");
}
delay(1000);
}

```

```

if( digitalRead(Mains_Power_Pin) == HIGH )
{
    digitalWrite(Mains_Generator_Relay,HIGH);
    digitalWrite(motor,HIGH);
    lcd.setCursor(12, 1);
    lcd.print("MAI");
}
else
{
    digitalWrite(motor,HIGH);
    digitalWrite(Mains_Generator_Relay,LOW);
    lcd.setCursor(12, 1);
    lcd.print("GEN");
}

Button_Debounce();
}

void Button_Debounce()
{
    // read the state of the switch into a local variable:
    int reading = digitalRead(Power_Detection_Activator);

    // check to see if you just pressed the button
    // (i.e. the input went from LOW to HIGH), and you've waited
    // long enough since the last press to ignore any noise:

    // If the switch changed, due to noise or pressing:

```

```

if (reading != lastButtonState) {
    // reset the debouncing timer
    lastDebounceTime = millis();
}

if ((millis() - lastDebounceTime) > debounceDelay) {
    // whatever the reading is at, it's been there for longer
    // than the debounce delay, so take it as the actual current state:

    // if the button state has changed:
    if (reading != buttonState) {
        buttonState = reading;

        // only toggle the LED if the new button state is HIGH
        if (buttonState == HIGH) {
            Active = !Active;
        }
    }
}

// set the LED:
digitalWrite(Indicator_Pin, Active);

// save the reading. Next time through the loop,
// it'll be the lastButtonState:
lastButtonState = reading;
}

```